

# MID-CONTINENT ENERGY EXCHANGE

## Oil & Gas Asset Auctions



### Data Packet

# 2019 5K Spherical Sand Separator

Equipment in  
Gregg County, TX

***In this Document:***

[Summary](#)

[Photos](#)

[Specifications](#)



# ***Lot Summary***

County/State: Gregg County, TX

Equipment Name: 2019 5K Spherical Sand Separator (Qty 1)

Description: Located in White Oak, Texas 75693.  
It was leased for 7 months from October 2019 -  
April 2020.

Note: Buyer is responsible for shipping.

Disclaimer: Bidders must conduct their own due diligence prior to bidding at the auction. Bidders shall rely upon their own evaluations of the properties and not upon any representation either oral or written provided here. This is a summary of information provided by the seller to Mid-Continent Energy Exchange.



***Photos***









SFI-48IDX5K-102

1B 993

CERTIFIED BY



Synergy Fabrication Inc.  
1432 E. Devitt St.  
Fort Worth, TX 76119

M.A.W.P.

5,000 PSIG @ 200°F

M.D.M.T.

-20°F @ 5,000 PSIG



SERIAL #:

SFI-48IDX5K-102

YEAR BUILT:

2019

U

W

RT-1

HT



# ***Specifications***







**Synergy Fabrication, Inc.**

**DATA BOOK**

**30-06 LEASING**

**48" 5,000psi**

**Hemisphere Separator**

**S/N:**

**SFI-48IDX5K-102**

## TABLE OF CONTENTS

### VESSEL INFORMATION:

U1A, INSPECTION CHECKLIST & NAMEPLATE.....	3
CALCULATIONS .....	11
DRAWING.....	97
MTR'S.....	103
WELDERS LOG .....	116
HYDRO REPORT.....	119
Heat Treat Charts/X-Ray Reports.....	121/126
Taylor PSV Certification.....	129



# **U1a – Manufacturer's Data Report**

**FORM U-1A MANUFACTURER'S DATA REPORT FOR PRESSURE VESSELS**  
**(Alternative Form for Single-Chamber, Completely Shop- or Field-Fabricated Vessels Only)**  
**As Required by the Provisions of the ASME Boiler and Pressure Vessel Code Rules, Section VIII, Division 1**

1. Manufactured and certified by Synergy Fabrication, Inc., 1432 E. Devitt St., Fort Worth, Texas 76119

(Name and address of Manufacturer)

2. Manufactured for Built For Stock  
 (Name and address of Purchaser)

3. Location of installation Unknown  
 (Name and address)

4. Type Spherical Tank SFI-48IDX5K-102 ---- SFI-48IDX5K-XXXR.6E 993 2019  
 (Horizontal or vertical, tank) (Manufacturer's serial number) (CRN) (Drawing number) (National Board number) (Year built)

5. ASME Code, Section VIII, Div. 1 2017 ---- ----  
 (Edition and Addenda, if applicable (date)) (Code Case number) [Special service per UG-120(d)]

6. Shell --- --- --- --- ---  
 (Material spec. number, grade) (Nominal thickness) (Corr. allow.) (Inner diameter) [Length (overall)]

Body Flanges on Shells												
No.	Type	ID	OD	Flange Thk	Min Hub Thk	Material	How Attached	Location	Bolting			
									Num & Size	Bolting Material	Washer (OD, ID, thk)	Washer Material
---	---	---	---	---	---	---	---	---	---	---	---	---

7. Seams --- --- --- 1150°F 2.50 Type 1 Full 100 1  
 (Long. (welded, dbl., singl., lap, butt)) (R.T. (spot or full)) (Eff., %) (H.T. temp.) (Time, hr) (Girth (welded, dbl., singl., lap, butt)) (R.T. (spot or full)) (Eff., %) (No. of courses)

8. Heads: (a) Material SA-516-70N (b) Material SA-516-70N  
 (Spec. no., grade) (Spec. no., grade)

	Location (Top, Bottom, Ends)	Minimum Thickness	Corrosion Allowance	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure (Convex or Concave)
(a)	End	3.10"	0"	---	---	---	---	24" IR	---	Concave
(b)	End	3.10"	0"	---	---	---	---	24" IR	---	Concave

Body Flanges on Heads												
	Location	Type	ID	OD	Flange Thk	Min Hub Thk	Material	How Attached	Bolting			
									Num & Size	Bolting Material	Washer (OD, ID, thk)	Washer Material
(a)	---	---	---	---	---	---	---	---	---	---	---	---
(b)												

9. MAWP 5,000 psi --- 200°F ---  
 (Internal) (External) at max. temp. (Internal) (External)

Min. design metal temp. -20°F at 5,000 psi . Hydro., pneu., or comb. test pressure Hydro 6,500 psi .

Proof test --- .

10. Nozzles, inspection, and safety valve openings:

Purpose (Inlet, Outlet, Drain, etc.)	No.	Diameter or Size	Type	Material		Nozzle Thickness		Reinforcement Material	Attachment Details		Location (Insp. Open.)
				Nozzle	Flange	Nom.	Corr.		Nozzle	Flange	
Inlet	1	4"	2500RTJLWN	SA-105	---	1.25"	0"	Inherent	UW-16.1(c)	---	Head (a)
Gas Outlet	1	3"	2500RTJLWN	SA-105	---	1.125"	0"	SA-516-70	UW-16.1(a-1)	---	Head (a)
Drain	1	3"	2500RTJLWN	SA-105	---	1.125"	0"	SA-516-70	UW-16.1(a-1)	---	Head (b)
PSV	2	1"	TOL	SA-105	---	CL6000	0"	Inherent	UW-16.1(a)	---	Head (a)
Utility	1	1/2"	TOL	SA-105	---	CL6000	0"	Inherent	UW-16.1(a)	---	Head (a)
---	---	---	---	---	---	---	---	---	---	---	---
---	---	---	---	---	---	---	---	---	---	---	---

11. Supports: Skirt No Lugs 4 Legs 4 Other --- Attached Head/Welded  
 (Yes or no) (Number) (Number) (Describe) (Where and how)

12. Remarks: Manufacturer's Partial Data Reports properly identified and signed by Commissioned Inspectors have been furnished for the following items of the report:

(Name of part, item number, Manufacturer's name and identifying stamp)

Material/Productions at -20°F. Not for Lethal or Corrosive Service, Pressure Relief per UG-125. Vessel designed per UG-22(a) Only.

D.M.



## FORM U-1A

Page 2 of 2

Manufactured by Synergy Fabrication, Inc., 1432 E. Devitt St., Fort Worth, Texas 76119  
Manufacturer's Serial No. SFI-48IDX5K-102 CRN ----- National Board No. 993

## CERTIFICATE OF SHOP/FIELD COMPLIANCE

We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME BOILER AND PRESSURE VESSEL CODE, Section VIII, Division 1. "U" Certificate of Authorization number 49,581 expires February 20, 2021.

Date 8-19-19 Co. name Synergy Fabrication, Inc. Signed J. M. Martin  
(Manufacturer) (Representative)

## CERTIFICATE OF SHOP/FIELD INSPECTION

Vessel constructed by Synergy Fabrication, Inc. at Fort Worth, Texas.  
I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and employed by OneCIS Insurance Co. of Lynn, MA

have inspected the component described in this Manufacturer's Data Report on 8-19-19, and state that, to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with ASME BOILER AND PRESSURE VESSEL CODE, Section VIII, Division 1. By signing this certificate neither the Inspector nor his/her employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his/her employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 8-19-19 Signed [Signature] Commissions NB 16591  
(Authorized Inspector) (National Board Authorized Inspector Commission number)

# INSPECTION CHECKLIST

PROJECT NUMBER \_\_\_\_\_ DATE 5-26-2019 AI ASSIGNED [Signature] ALTERNATE AI \_\_\_\_\_

ITEM NUMBER 102 SERIAL# SFI-4810XSK-102 NAT'LBDNo. 993

DWG & REV NO.: SFI-4810XSK-XXX R.6E

**NOTE: DONOT INITIAL A LINE UNTIL INSPECTION INDICATED IS COMPLETE.**

MAWP INT.: 5,000 EXT. - AT 200°F MDMT: -20 °F AT 5,000 PSI

DESIGN FOR SPECIAL SERVICE (L, UB, LT): YES \_\_\_\_\_ NO ☒ I.T. REQ'D: YES ☒ NO \_\_\_\_\_

1. CALCS. & DWG. REVIEWED BY AI: LP DATE 1-30-19 QUESTIONS \_\_\_\_\_

SIZE: O.D. 48" I.D. \_\_\_\_\_ O.A.L. \_\_\_\_\_ NUMBER OF COURSES \_\_\_\_\_

## MATERIAL INSPECTION

2. MILL TEST REPORTS: REVIEWED BY	QC <u>Dm</u>	DATE <u>5-17-19</u>	AI <u>[Signature]</u>	DATE <u>8-9-19</u>
3. PLATE: SPEC., GRADE & THICKNESS	QC <u>[Signature]</u>	DATE <u>[Signature]</u>	AI <u>[Signature]</u>	DATE <u>[Signature]</u>
SURFACE & EDGE CONDITION	QC <u>[Signature]</u>	DATE <u>[Signature]</u>	AI <u>[Signature]</u>	DATE <u>[Signature]</u>
4. PIPE: SPEC., GRADE & THICKNESS	QC <u>[Signature]</u>	DATE <u>[Signature]</u>	AI <u>[Signature]</u>	DATE <u>[Signature]</u>
SURFACE AND EDGE CONDITION	QC <u>[Signature]</u>	DATE <u>[Signature]</u>	AI <u>[Signature]</u>	DATE <u>[Signature]</u>
5. HEADS: SPEC., GRADE & THICKNESS	QC <u>[Signature]</u>	DATE <u>[Signature]</u>	AI <u>[Signature]</u>	DATE <u>[Signature]</u>
CONDITION & SHAPE UG-81	QC <u>[Signature]</u>	DATE <u>[Signature]</u>	AI <u>[Signature]</u>	DATE <u>[Signature]</u>
& UCS -79 (D) REQ'MTS.	QC <u>[Signature]</u>	DATE <u>[Signature]</u>	AI <u>[Signature]</u>	DATE <u>[Signature]</u>
6. REINFORCING PADS: SPEC, SIZE, THICKNESS	QC <u>[Signature]</u>	DATE <u>[Signature]</u>	AI <u>[Signature]</u>	DATE <u>[Signature]</u>
7. FLANGES: SPEC., RATING, BORE & SIZE	QC <u>Dm</u>	DATE <u>5-17-19</u>	AI <u>[Signature]</u>	DATE <u>8-19-19</u>

## FABRICATION INSPECTION

8. SHELL SIZE (TO MATCH HEADS) _____ SH & HD BEVELS: _____	QC <u>Dm</u>	AI <u>[Signature]</u>
9. OUT OF ROUNDNESS _____	QC <u>[Signature]</u>	AI <u>[Signature]</u>
10. EDGE OFFSET, LONG & GIRTH SEAMS _____	QC <u>[Signature]</u>	AI <u>[Signature]</u>
11. QUALIFIED WELD PROCEDURES, WELDERS & WELD ID _____	QC <u>[Signature]</u>	AI <u>[Signature]</u>
12. CAT. A _____ B _____ C _____ D _____ WELD REINFORCEMENT & SIZE _____	QC <u>[Signature]</u>	AI <u>[Signature]</u>
13. POST WELD HEAT TREAT REQ'D: YES <input checked="" type="checkbox"/> NO _____ CK'D BY _____	QC <u>[Signature]</u>	AI <u>[Signature]</u>
14. PT OR MT REQ'D: YES _____ NO <input checked="" type="checkbox"/> CK'D BY _____	QC <u>[Signature]</u>	AI <u>[Signature]</u>
15. EXTENT OF RT: (NONE <u>RT-1</u> RT-2, RT-3, RT-4) NUMBER OF FILM _____	QC <u>Dm</u>	AI <u>[Signature]</u>
16. RT INTERPRETATION BY: _____	QC _____	DATE _____
17. ALL FIM REVIEWED AND ACCEPTED BY AI: <u>[Signature]</u>	DATE <u>8-6-19</u>	
18. VESSEL INTERNAL INSPECTION BY: QC <u>Dm 8-2-2019</u>	AI <u>[Signature]</u>	DATE <u>8-2-19</u>
19. HYDROSTATIC TEST <u>6,500</u> PSI	QC <u>Dm 8-8-2019</u>	AI <u>[Signature]</u> DATE <u>8-9-19</u>
20. NAMEPLATE CK'D BY: QC <u>Dm 8-19-19</u>	AI <u>[Signature]</u>	DATE <u>8-19-19</u>
21. MANUFACTURER'S DATA REPORT: QC <u>Dm 8-19-19</u>	SIGNED BY AI <u>[Signature]</u>	DATE <u>8-19-19</u>

**NOTE: AI "HOLD" OR "INSPECTION POINTS" TO BE INDICATED BY NUMBER HERE: 1, 2, 3, 7-21**

WHEN ONLY PARTIAL INSPECTION IS PERFORMED, LIST ITEM NUMBERS, DATE AND INITIAL:

Head fit 8-2-19



JB 993

CERTIFIED BY



Synergy Fabrication Inc.  
1432 E. Devitt St.  
Fort Worth, TX 76119

M.A.W.P. 5.000 PSIG • 200°F

M.D.M.T. -20°F • 5.000 PSIG



SERIAL #: SFI-4810X5K-102

YEAR BUILT: 2019

U

W

RT-I


HT

# **Calculations**

# Synergy Fabrication, Inc.

1432 E. Devitt St.

Fort Worth, TX 76119



## COMPRESS Pressure Vessel Design Calculations

**Item:** 48" I.D. 5k Spherical Sand Separator  
**Vessel No:** SFI-48IDX5K-XXX DRAWING Rev. 6A  
**Customer:** CIMAREX  
**Designer:** MS / Kevin McFarland  
**Date:** 2/12/2018 / REV 6E: 2/6/2019

3 5/8" thk heads with 2 x 1" PSV set ups  
5/8" Thk Repads on Top and Bottom.

FEA OF EXEMPT NOZZLES ADDED  
Rev 6E: Drain Noz size updated to 3" 2500#

# Table of Contents

<a href="#"><u>Deficiencies Summary</u></a>	1/86
<a href="#"><u>Nozzle Schedule</u></a>	2/86
<a href="#"><u>Nozzle Summary</u></a>	3/86
<a href="#"><u>Pressure Summary</u></a>	4/86
<a href="#"><u>Revision History</u></a>	6/86
<a href="#"><u>Settings Summary</u></a>	7/86
<a href="#"><u>Radiography Summary</u></a>	9/86
<a href="#"><u>Thickness Summary</u></a>	10/86
<a href="#"><u>Weight Summary</u></a>	11/86
<a href="#"><u>Hydrostatic Test</u></a>	12/86
<a href="#"><u>Hemi Head #1</u></a>	13/86
<a href="#"><u>Hemi Head #2</u></a>	16/86
<a href="#"><u>INLET (N1)</u></a>	19/86
<a href="#"><u>GAS OUTLET (N2)</u></a>	22/86
<a href="#"><u>DRAIN (N3)</u></a>	26/86
<a href="#"><u>PSV (N4A)</u></a>	30/86
<a href="#"><u>PSV (N4B)</u></a>	33/86
<a href="#"><u>P.I. (N5)</u></a>	36/86
<a href="#"><u>Support Lugs #1</u></a>	39/86
<a href="#"><u>Liquid Level bounded by Hemi Head #2</u></a>	46/86
<a href="#"><u>PSV (N4A): FEA Results</u></a>	47/86
<a href="#"><u>P.I. (N5): FEA Results</u></a>	67/86



## Deficiencies Summary

### Deficiencies for [Support Lugs #1](#)

WRC 107: The local primary membrane stress (PL) is excessive (operating condition)

## Nozzle Schedule

Specifications									
Nozzle mark	Identifier	Size	Materials		Impact Tested	Normalized	Fine Grain	Flange	Blind
<a href="#">N1</a>	INLET	6.5 OD x 1.25	Nozzle	SA-105	No	No	No	NPS 4 Class 2500 LWN A105	No
<a href="#">N2</a>	GAS OUTLET	5.25 OD x 1.125	Nozzle	SA-105	No	No	No	NPS 3 Class 2500 LWN A105	No
			Pad	SA-516 70	No	No	No		
<a href="#">N3</a>	DRAIN	5.25 OD x 1.125	Nozzle	SA-105	No	No	No	NPS 3 Class 2500 LWN A105	No
			Pad	SA-516 70	No	No	No		
<a href="#">N4A</a>	PSV	NPS 1 Class 6000 - threaded	Nozzle	SA-105	No	No	No	N/A	No
<a href="#">N4B</a>	PSV	NPS 1 Class 6000 - threaded	Nozzle	SA-105	No	No	No	N/A	No
<a href="#">N5</a>	P.I.	NPS 0.5 Class 6000 - threaded	Nozzle	SA-105	No	No	No	N/A	No

## Nozzle Summary

Dimensions												
Nozzle mark	OD (in)	t <sub>n</sub> (in)	Req t <sub>n</sub> (in)	A <sub>1</sub> ?	A <sub>2</sub> ?	Shell			Reinforcement Pad		Corr (in)	A <sub>a</sub> /A <sub>r</sub> (%)
						Nom t (in)	Design t (in)	User t (in)	Width (in)	t <sub>pad</sub> (in)		
<a href="#">N1</a>	6.5	1.25	0.5883	Yes	Yes	3.1*	3.0774		N/A	N/A	0	100.6
<a href="#">N2</a>	5.25	1.125	0.4412	Yes	Yes	3.1*	3.0771		3	0.625	0	101.0
<a href="#">N3</a>	5.25	1.125	0.4414	Yes	Yes	3.1*	3.0784		3	0.625	0	100.8
<a href="#">N4A</a>	2.25	0.4675	0.2557	Yes	Yes	3.1*	N/A		N/A	N/A	0	Exempt
<a href="#">N4B</a>	2.25	0.4675	0.2557	Yes	Yes	3.1*	N/A		N/A	N/A	0	Exempt
<a href="#">N5</a>	1.5	0.33	0.1705	Yes	Yes	3.1*	N/A		N/A	N/A	0	Exempt
*Head minimum thickness after forming												

Definitions	
t <sub>n</sub>	Nozzle thickness
Req t <sub>n</sub>	Nozzle thickness required per UG-45/UG-16
Nom t	Vessel wall thickness
Design t	Required vessel wall thickness due to pressure + corrosion allowance per UG-37
User t	Local vessel wall thickness (near opening)
A <sub>a</sub>	Area available per UG-37, governing condition
A <sub>r</sub>	Area required per UG-37, governing condition
Corr	Corrosion allowance on nozzle wall

## Pressure Summary

Component Summary							
Identifier	P Design (psi)	T Design (°F)	MAWP (psi)	MAP (psi)	MDMT (°F)	MDMT Exemption	Impact Tested
<a href="#">Hemi Head #1</a>	5,000	200	5,035.41	5,036.56	-20.7	Note 1	Yes
<a href="#">Cylinder #1</a>	5,000	200	5,113.49	5,114.64	-22.6	Note 2	Yes
<a href="#">Hemi Head #2</a>	5,000	200	5,033.91	5,036.56	-20.7	Note 3	Yes
<a href="#">Support Lugs #1</a>	5,000	200	5,000	N/A	N/A	N/A	N/A
<a href="#">INLET (N1)</a>	5,000	200	5,009.53	5,010.21	-39	Note 4	No
<a href="#">GAS OUTLET (N2)</a>	5,000	200	5,011.43	5,011.71	-25.7	Nozzle	Note 5 No
						Pad	Note 6 No
<a href="#">DRAIN (N3)</a>	5,000	200	5,009.42	5,011.71	-25.7	Nozzle	Note 7 No
						Pad	Note 8 No
<a href="#">PSV (N4A)</a>	5,000	200	5,036.04	5,036.56	-55	Note 9	No
<a href="#">PSV (N4B)</a>	5,000	200	5,036.04	5,036.56	-55	Note 9	No
<a href="#">P.I. (N5)</a>	5,000	200	5,036.04	5,036.56	-55	Note 10	No

Chamber Summary	
Design MDMT	-20 °F
Rated MDMT	-20.7 °F @ 5,000 psi
MAWP hot & corroded	5,000 psi @ 200 °F
MAP cold & new	5,010.21 psi @ 70 °F
(1) This pressure chamber is not designed for external pressure.	



Notes for MDMT Rating		
Note #	Exemption	Details
1.	Material is impact tested per UG-84 to -20°F.	UCS-66(i) reduction of 0.7°F applied (ratio = 0.9928).
2.	Material is impact tested per UG-84 to -20°F.	UCS-66(i) reduction of 2.6°F applied (ratio = 0.9739).
3.	Material is impact tested per UG-84 to -20°F.	UCS-66(i) reduction of 0.7°F applied (ratio = 0.993).
4.	LWN rated MDMT per UCS-66(c)(4) Flange rated MDMT per UCS-66(b)(1)(b) = -39°F (Coincident ratio = 0.8105) Bolts rated MDMT per Fig UCS-66 note (c) = -55°F	
5.	LWN rated MDMT per UCS-66(c)(4) Flange rated MDMT per UCS-66(b)(1)(b) = -55°F (Coincident ratio = 0.8104) Bolts rated MDMT per Fig UCS-66 note (c) = -55°F	
6.	Pad impact test exemption temperature from Fig UCS-66 Curve B = 5°F 30°F MDMT reduction per UCS-68(c) applies. Fig UCS-66.1 MDMT reduction = 0.7°F, (coincident ratio = 0.9926)	UCS-66 governing thickness = 0.625 in.
7.	LWN rated MDMT per UCS-66(c)(4) Flange rated MDMT per UCS-66(b)(1)(b) = -55°F (Coincident ratio = 0.8108) Bolts rated MDMT per Fig UCS-66 note (c) = -55°F	
8.	Pad impact test exemption temperature from Fig UCS-66 Curve B = 5°F 30°F MDMT reduction per UCS-68(c) applies. Fig UCS-66.1 MDMT reduction = 0.7°F, (coincident ratio = 0.993)	UCS-66 governing thickness = 0.625 in.
9.	Nozzle impact test exemption temperature from Fig UCS-66 Curve B = -10.12°F 30°F MDMT reduction per UCS-68(c) applies. Fig UCS-66.1 MDMT reduction = 84.9°F, (coincident ratio = 0.4137) Rated MDMT of -125.02°F is limited to -55°F by UCS-66(b)(2)	UCS-66 governing thickness = 0.4675 in.
10.	Nozzle impact test exemption temperature from Fig UCS-66 Curve B = -20°F 30°F MDMT reduction per UCS-68(c) applies. Fig UCS-66.1 MDMT reduction = 113.6°F, (coincident ratio = 0.3744) Rated MDMT of -163.6°F is limited to -55°F by UCS-66(b)(2)	UCS-66 governing thickness = 0.33 in.

## Revision History

Revisions			
No.	Date	Operator	Notes
0	9/13/2016	Kevin McFarland	New vessel created ASME Section VIII Division 1 [COMPRESS 2015 Build 7510]
1	10/13/2017	msaff	Converted from ASME Section VIII Division 1, 2013 Edition to ASME Section VIII Division 1, 2015 Edition. During the conversion, changes may have been made to your vessel (some may be listed above). Please check your vessel carefully.
2	12/18/2017	msaff	Converted from ASME Section VIII Division 1, 2015 Edition to ASME Section VIII Division 1, 2017 Edition. During the conversion, changes may have been made to your vessel (some may be listed above). Please check your vessel carefully.

## Settings Summary

COMPRESS 2018 Build 7820	
ASME Section VIII Division 1, 2017 Edition	
Units	U.S. Customary
Datum Line Location	0.00" from bottom seam
Vessel Design Mode	Design Mode
Minimum thickness	0.0625" per UG-16(b)
Design for cold shut down only	No
Design for lethal service (full radiography required)	No
Design nozzles for	Design P only
Corrosion weight loss	100% of theoretical loss
UG-23 Stress Increase	1.20
Skirt/legs stress increase	1.0
Minimum nozzle projection	1"
Juncture calculations for $\alpha > 30$ only	Yes
Preheat P-No 1 Materials > 1.25" and $\leq 1.50$ " thick	No
UG-37(a) shell tr calculation considers longitudinal stress	No
Cylindrical shells made from pipe are entered as minimum thickness	No
Nozzles made from pipe are entered as minimum thickness	No
ASME B16.9 fittings are entered as minimum thickness	No
Butt welds	Tapered per Figure UCS-66.3(a)
Disallow Appendix 1-5, 1-8 calculations under 15 psi	No
Hydro/Pneumatic Test	
Shop Hydrotest Pressure	1.3 times vessel MAWP [UG-99(b)]
Test liquid specific gravity	1.00
Maximum stress during test	90% of yield
Required Marking - UG-116	
UG-116(e) Radiography	RT1
UG-116(f) Postweld heat treatment	HT
Code Cases\Interpretations	
Use Code Case 2547	No
Use Code Case 2695	No
Use Code Case 2901	No
Apply interpretation VIII-1-83-66	Yes



Apply interpretation VIII-1-86-175	Yes
Apply interpretation VIII-1-01-37	Yes
Apply interpretation VIII-1-01-150	Yes
Apply interpretation VIII-1-07-50	Yes
Apply interpretation VIII-1-16-85	No
No UCS-66.1 MDMT reduction	No
No UCS-68(c) MDMT reduction	No
Disallow UG-20(f) exemptions	No
<b>UG-22 Loadings</b>	
UG-22(a) Internal or External Design Pressure	Yes
UG-22(b) Weight of the vessel and normal contents under operating or test conditions	Yes
UG-22(c) Superimposed static reactions from weight of attached equipment (external loads)	No
UG-22(d)(2) Vessel supports such as lugs, rings, skirts, saddles and legs	Yes
UG-22(f) Wind reactions	No
UG-22(f) Seismic reactions	No
UG-22(j) Test pressure and coincident static head acting during the test:	No
Note: UG-22(b),(c) and (f) loads only considered when supports are present.	

License Information	
Company Name	Synergy Fabrication, Inc.
License	Commercial
License Key ID	38280
Support Expires	April 26, 2019

## Radiography Summary

UG-116 Radiography							
Component	Longitudinal Seam		Top Circumferential Seam		Bottom Circumferential Seam		Mark
	Category (Fig UW-3)	Radiography / Joint Type	Category (Fig UW-3)	Radiography / Joint Type	Category (Fig UW-3)	Radiography / Joint Type	
<a href="#">Hemi Head #1</a>	N/A	Seamless No RT	N/A	N/A	A	Full UW-11(a) / Type 1	RT1
<a href="#">Cylinder #1</a>	N/A	Seamless No RT	A	Full UW-11(a) / Type 1	A	Full UW-11(a) / Type 1	RT1
<a href="#">Hemi Head #2</a>	N/A	Seamless No RT	A	Full UW-11(a) / Type 1	N/A	N/A	RT1
Nozzle	Longitudinal Seam		Nozzle to Vessel Circumferential Seam		Nozzle free end Circumferential Seam		
<a href="#">INLET (N1)</a>	N/A	Seamless No RT	D	N/A / Type 7	C	N/A	N/A
<a href="#">GAS OUTLET (N2)</a>	N/A	Seamless No RT	D	N/A / Type 7	C	N/A	N/A
<a href="#">PSV (N4A)</a>	N/A	Seamless No RT	D	N/A / Type 7	N/A	N/A	N/A
<a href="#">P.I. (N5)</a>	N/A	Seamless No RT	D	N/A / Type 7	N/A	N/A	N/A
<a href="#">PSV (N4B)</a>	N/A	Seamless No RT	D	N/A / Type 7	N/A	N/A	N/A
<a href="#">DRAIN (N3)</a>	N/A	Seamless No RT	D	N/A / Type 7	C	N/A	N/A
Nozzle Flange	Longitudinal Seam		Flange Face		Nozzle to Flange Circumferential Seam		
<a href="#">ASME B16.5/16.47 flange attached to INLET (N1)</a>	N/A	Seamless No RT	N/A	N/A / Gasketed	C	N/A	N/A
<a href="#">ASME B16.5/16.47 flange attached to GAS OUTLET (N2)</a>	N/A	Seamless No RT	N/A	N/A / Gasketed	C	N/A	N/A
<a href="#">ASME B16.5/16.47 flange attached to DRAIN (N3)</a>	N/A	Seamless No RT	N/A	N/A / Gasketed	C	N/A	N/A
UG-116(e) Required Marking: <b>RT1</b>							

## Thickness Summary

Component Data								
Component Identifier	Material	Diameter (in)	Length (in)	Nominal t (in)	Design t (in)	Total Corrosion (in)	Joint E	Load
<a href="#">Hemi Head #1</a>	SA-516 70	48 ID	27.1	3.1*	3.0777	0	1.00	Internal
<a href="#">Cylinder #1</a>	SA-516 70	48 ID	0.0625	7.25	7.0608	0	1.00	Internal
<a href="#">Hemi Head #2</a>	SA-516 70	48 ID	27.1	3.1*	3.0786	0	1.00	Weight
*Head minimum thickness after forming								

Definitions	
Nominal t	Vessel wall nominal thickness
Design t	Required vessel thickness due to governing loading + corrosion
Joint E	Longitudinal seam joint efficiency
Load	
Internal	Circumferential stress due to internal pressure governs
External	External pressure governs
Wind	Combined longitudinal stress of pressure + weight + wind governs
Seismic	Combined longitudinal stress of pressure + weight + seismic governs



## Weight Summary

Weight (lb) Contributed by Vessel Elements											
Component	Metal New*	Metal Corroded	Insulation	Insulation Supports	Lining	Piping + Liquid	Operating Liquid		Test Liquid		Surface Area ft <sup>2</sup>
							New	Corroded	New	Corroded	
<a href="#">Hemi Head #1</a>	3,546.2	3,546.2	0	0	0	0	1,049.7	1,049.7	1,049.8	1,049.8	32
<a href="#">Cylinder #1</a>	22.3	22.3	0	0	0	0	4.1	4.1	4.1	4.1	0
<a href="#">Hemi Head #2</a>	3,583.8	3,583.8	0	0	0	0	1,046.4	1,046.4	1,046.4	1,046.4	32
<a href="#">Support Lugs #1</a>	262.3	262.3	0	0	0	0	0	0	0	0	16
<b>TOTAL:</b>	<b>7,414.6</b>	<b>7,414.6</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>2,100.2</b>	<b>2,100.2</b>	<b>2,100.3</b>	<b>2,100.3</b>	<b>80</b>
*Shells with attached nozzles have weight reduced by material cut out for opening.											

Weight (lb) Contributed by Attachments											
Component	Body Flanges		Nozzles & Flanges		Packed Beds	Ladders & Platforms	Trays	Tray Supports	Rings & Clips	Vertical Loads	Surface Area ft <sup>2</sup>
	New	Corroded	New	Corroded							
<a href="#">Hemi Head #1</a>	0	0	371.9	371.9	0	0	0	0	0	0	4
<a href="#">Cylinder #1</a>	0	0	0	0	0	0	0	0	0	0	0
<a href="#">Hemi Head #2</a>	0	0	128.9	128.9	0	0	0	0	0	0	2
<b>TOTAL:</b>	<b>0</b>	<b>0</b>	<b>500.9</b>	<b>500.9</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>6</b>

Vessel Totals		
	New	Corroded
Operating Weight (lb)	10,016	10,016
Empty Weight (lb)	7,915	7,915
Test Weight (lb)	10,016	10,016
Surface Area (ft <sup>2</sup> )	86	-
Capacity** (US gal)	251	251
**The vessel capacity does not include volume of nozzle, piping or other attachments.		

Vessel Lift Condition		
Vessel Lift Weight, New (lb)		7,915
Center of Gravity from Datum (in)		0.2319

## Hydrostatic Test

### Horizontal shop hydrostatic test based on MAWP per UG-99(b)

$$\begin{aligned}
 \text{Gauge pressure at } 70^{\circ}\text{F} &= \\
 &= 1.3 \cdot \text{MAWP} \cdot \text{LSR} \\
 &= 1.3 \cdot 5,000 \cdot 1 \\
 &= 6,500 \text{ psi}
 \end{aligned}$$

Horizontal shop hydrostatic test				
Identifier	Local test pressure (psi)	Test liquid static head (psi)	UG-99(b) stress ratio	UG-99(b) pressure factor
Hemi Head #1 (1)	6,501.733	1.733	1	1.30
Cylinder #1	6,501.733	1.733	1	1.30
Hemi Head #2	6,501.733	1.733	1	1.30
DRAIN (N3)	6,500.921	0.921	1	1.30
GAS OUTLET (N2)	6,500.921	0.921	1	1.30
INLET (N1)	6,500.939	0.939	1	1.30
P.I. (N5)	6,500.882	0.882	1	1.30
PSV (N4A)	6,501.382	1.382	1	1.30
PSV (N4B)	6,500.411	0.411	1	1.30
(1) Hemi Head #1 limits the UG-99(b) stress ratio. (2) The zero degree angular position is assumed to be up, and the test liquid height is assumed to the top-most flange.				

The field test condition has not been investigated.

The test temperature of 70 °F is warmer than the minimum recommended temperature of 9.3 °F so the brittle fracture provision of UG-99(h) has been met.

## Hemi Head #1

ASME Section VIII Division 1, 2017 Edition				
Component		Hemispherical Head		
Material		SA-516 70 (II-D p. 18, In. 33)		
Attached To		Cylinder #1		
Impact Tested	Normalized	Fine Grain Practice	PWHT	Optimize MDMT Find MAWP
Yes (-20°F)	Yes	No	Yes	No
		Design Pressure (psi)	Design Temperature (°F)	Design MDMT (°F)
Internal		5,000	200	-20
Static Liquid Head				
Condition		P <sub>s</sub> (psi)	H <sub>s</sub> (in)	SG
Operating		1.14	31.6323	1
Test horizontal		1.73	48	1
Dimensions				
Inner Diameter		48"		
Minimum Thickness		3.1"		
Corrosion	Inner	0"		
	Outer	0"		
Weight and Capacity				
		Weight (lb)		Capacity (US gal)
New		3,546.19		125.34
Corroded		3,546.19		125.34
Radiography				
Category A joints - Long Seam		Seamless No RT		
Category A joints - Circ Seam		Full UW-11(a) Type 1		

Results Summary	
Governing condition	Internal pressure
Minimum thickness per UG-16	$0.0625" + 0" = 0.0625"$
Design thickness due to internal pressure (t)	<a href="#">3.0777"</a>
Design thickness due to combined loadings + corrosion	<a href="#">3.0759"</a>
Maximum allowable working pressure (MAWP)	<a href="#">5.035.41 psi</a>
Maximum allowable pressure (MAP)	<a href="#">5.036.56 psi</a>
Rated MDMT	-20.7 °F

UCS-66 Material Toughness Requirements	
Material impact test temperature per UG-84 =	-20 °F
$t_r = 5,001.14 \cdot 24 / (2 \cdot 20,000 \cdot 1 - 0.2 \cdot 5,001.14) =$	3.0776"
Stress ratio $= t_r \cdot E^* / (t_n - c) = 3.0776 \cdot 1 / (3.1 - 0) =$	0.9928
UCS-66(i) reduction in MDMT, $T_R$ from Fig UCS-66.1 =	0.7 °F
$MDMT = \max[T_{\text{impact}} - T_R, -155] = \max[-20 - 0.7, -155] =$	-20.7 °F
Design MDMT of -20 °F is acceptable.	

#### Design thickness, (at 200 °F) UG-32(e)

$$\begin{aligned}
 t &= P \cdot R / (2 \cdot S \cdot E - 0.20 \cdot P) + \text{Corrosion} \\
 &= 5,001.14 \cdot 24 / (2 \cdot 20,000 \cdot 1.00 - 0.20 \cdot 5,001.14) + 0 \\
 &= \text{3.0777"}
 \end{aligned}$$

#### Maximum allowable working pressure, (at 200 °F) UG-32(e)

$$\begin{aligned}
 P &= 2 \cdot S \cdot E \cdot t / (R + 0.20 \cdot t) - P_s \\
 &= 2 \cdot 20,000 \cdot 1.00 \cdot 3.1 / (24 + 0.20 \cdot 3.1) - 1.14 \\
 &= \text{5.035.41 psi}
 \end{aligned}$$

#### Maximum allowable pressure, (at 70 °F) UG-32(e)

$$\begin{aligned}
 P &= 2 \cdot S \cdot E \cdot t / (R + 0.20 \cdot t) \\
 &= 2 \cdot 20,000 \cdot 1.00 \cdot 3.1 / (24 + 0.20 \cdot 3.1) \\
 &= \text{5.036.56 psi}
 \end{aligned}$$

#### % Extreme fiber elongation - UCS-79(d)

$$\begin{aligned}
 EFE &= (75 \cdot t / R_f) \cdot (1 - R_f / R_o) \\
 &= (75 \cdot 3.1 / 25.55) \cdot (1 - 25.55 / \infty) \\
 &= 9.0998\%
 \end{aligned}$$

Thickness Required Due to Pressure + External Loads								
Condition	Pressure P (psi)	Allowable Stress Before UG-23 Stress Increase ( psi)		Temperature ( °F)	Corrosion C (in)	Load	Req'd Thk Due to Tension (in)	Req'd Thk Due to Compression (in)
		S <sub>t</sub>	S <sub>c</sub>					
Operating, Hot & Corroded	5,000	20,000	17,460	200	0	Weight	3.0759	3.0755
Operating, Hot & New	5,000	20,000	17,460	200	0	Weight	3.0759	3.0755
Hot Shut Down, Corroded	0	20,000	17,460	200	0	Weight	0.0012	0.0016
Hot Shut Down, New	0	20,000	17,460	200	0	Weight	0.0012	0.0016
Empty, Corroded	0	20,000	17,460	70	0	Weight	0.0012	0.0016
Empty, New	0	20,000	17,460	70	0	Weight	0.0012	0.0016
Hot Shut Down, Corroded, Weight & Eccentric Moments Only	0	20,000	17,460	200	0	Weight	0.0012	0.0016



## Hemi Head #2

ASME Section VIII Division 1, 2017 Edition				
Component		Hemispherical Head		
Material		SA-516 70 (II-D p. 18, In. 33)		
Attached To		Cylinder #1		
Impact Tested	Normalized	Fine Grain Practice	PWHT	Optimize MDMT/ Find MAWP
Yes (-20°F)	Yes	No	Yes	No
		Design Pressure (psi)	Design Temperature (°F)	Design MDMT (°F)
Internal		5,000	200	-20
Static Liquid Head				
Condition		P <sub>s</sub> (psi)	H <sub>s</sub> (in)	SG
Operating		2.01	55.6948	1
Test horizontal		1.73	48	1
Dimensions				
Inner Diameter		48"		
Minimum Thickness		3.1"		
Corrosion	Inner	0"		
	Outer	0"		
Weight and Capacity				
		Weight (lb)		Capacity (US gal)
New		3,583.83		125.34
Corroded		3,583.83		125.34
Radiography				
Category A joints - Long Seam		Seamless No RT		
Category A joints - Circ Seam		Full UW-11(a) Type 1		

Results Summary	
Governing condition	Operating, Hot & Corroded
Minimum thickness per UG-16	$0.0625" + 0" = 0.0625"$
Design thickness due to internal pressure (t)	<a href="#">3.0782"</a>
Design thickness due to combined loadings + corrosion	<a href="#">3.0786"</a>
Maximum allowable working pressure (MAWP)	5,033.91 psi
Maximum allowable pressure (MAP)	<a href="#">5,036.56 psi</a>
Rated MDMT	-20.7 °F

UCS-66 Material Toughness Requirements	
Material impact test temperature per UG-84 =	-20 °F
$t_r = 5,002.01 \cdot 24 / (2 \cdot 20,000 \cdot 1 - 0.2 \cdot 5,002.01) =$	3.0782"
Stress ratio $= t_r \cdot E^* / (t_n - c) = 3.0782 \cdot 1 / (3.1 - 0) =$	0.993
UCS-66(i) reduction in MDMT, $T_R$ from Fig UCS-66.1 =	0.7 °F
$MDMT = \max[T_{\text{impact}} - T_R, -155] = \max[-20 - 0.7, -155] =$	-20.7 °F
Design MDMT of -20 °F is acceptable.	

#### Design thickness, (at 200 °F) UG-32(e)

$$\begin{aligned}
 t &= P \cdot R / (2 \cdot S \cdot E - 0.20 \cdot P) + \text{Corrosion} \\
 &= 5,002.01 \cdot 24 / (2 \cdot 20,000 \cdot 1.00 - 0.20 \cdot 5,002.01) + 0 \\
 &= \a href="#">3.0782"
 \end{aligned}$$

#### Maximum allowable working pressure, (at 200 °F) UG-32(e)

$$\begin{aligned}
 P &= 2 \cdot S \cdot E \cdot t / (R + 0.20 \cdot t) - P_s \\
 &= 2 \cdot 20,000 \cdot 1.00 \cdot 3.1 / (24 + 0.20 \cdot 3.1) - 2.01 \\
 &= \a href="#">5,034.55 \text{ psi}
 \end{aligned}$$

#### Maximum allowable pressure, (at 70 °F) UG-32(e)

$$\begin{aligned}
 P &= 2 \cdot S \cdot E \cdot t / (R + 0.20 \cdot t) \\
 &= 2 \cdot 20,000 \cdot 1.00 \cdot 3.1 / (24 + 0.20 \cdot 3.1) \\
 &= \a href="#">5,036.56 \text{ psi}
 \end{aligned}$$


#### % Extreme fiber elongation - UCS-79(d)

$$\begin{aligned}
 EFE &= (75 \cdot t / R_f) \cdot (1 - R_f / R_o) \\
 &= (75 \cdot 3.1 / 25.55) \cdot (1 - 25.55 / \infty) \\
 &= 9.0998\%
 \end{aligned}$$

Thickness Required Due to Pressure + External Loads									
Condition	Pressure P (psi)	Allowable Stress Before UG-23 Stress Increase ( psi)		Temperature ( °F)	Corrosion C (in)	Location	Load	Req'd Thk Due to Tension (in)	Req'd Thk Due to Compression (in)
		S <sub>t</sub>	S <sub>c</sub>						
Operating, Hot & Corroded	5,000	20,000	17,460	200	0	Top	Weight	3.0757	3.0753
						Bottom	Weight	3.0786	3.0786
Operating, Hot & New	5,000	20,000	17,460	200	0	Top	Weight	3.0757	3.0753
						Bottom	Weight	3.0786	3.0786
Hot Shut Down, Corroded	0	20,000	17,460	200	0	Top	Weight	0.0014	0.0018
						Bottom	Weight	0.0017	0.0017
Hot Shut Down, New	0	20,000	17,460	200	0	Top	Weight	0.0014	0.0018
						Bottom	Weight	0.0017	0.0017
Empty, Corroded	0	20,000	17,460	70	0	Top	Weight	0.0014	0.0018
						Bottom	Weight	0.001	0.001
Empty, New	0	20,000	17,460	70	0	Top	Weight	0.0014	0.0018
						Bottom	Weight	0.001	0.001
Hot Shut Down, Corroded, Weight & Eccentric Moments Only	0	20,000	17,460	200	0	Top	Weight	0.0014	0.0018
						Bottom	Weight	0.0017	0.0017

# INLET (N1)

## ASME Section VIII Division 1, 2017 Edition



Note: round inside edges per UG-76(c)

### Location and Orientation

Located on	Hemi Head #1
Orientation	90°
Nozzle center line offset to datum line	15.0625"
Calculated as hillside	Yes (perpendicular)
Distance to head center, R	33"
Passes through a Category A joint	No

### Nozzle

Access opening	No
Material specification	SA-105 (II-D p. 18, In. 19)
Inside diameter, new	4"
Nominal wall thickness	1.25"
Corrosion allowance	0"
Opening chord length	4.9734"
Projection available outside vessel, L <sub>pr</sub>	5.3298"
Internal projection, h <sub>new</sub>	3.5"
Projection available outside vessel to flange face, L <sub>f</sub>	8.5798"
Local vessel minimum thickness	3.1"
Liquid static head included	0.67 psi
Longitudinal joint efficiency	1

### Welds

Inner fillet, Leg <sub>41</sub>	1.5"
---------------------------------	------

Lower fillet, Leg <sub>43</sub>	1"
Nozzle to vessel groove weld	3.1"

ASME B16.5-2013 Flange	
Description	NPS 4 Class 2500 LWN A105
Bolt Material	SA-193 B7 Bolt <= 2 1/2 (II-D p. 388, ln. 32)
Blind included	No
Rated MDMT	-39°F
Liquid static head	0.6 psi
MAWP rating	5,655 psi @ 200°F
MAP rating	6,170 psi @ 70°F
Hydrotest rating	9,275 psi @ 70°F
PWHT performed	Yes
Impact Tested	No
Notes	
Flange rated MDMT per UCS-66(b)(1)(b) = -39°F (Coincident ratio = 0.8105) Bolts rated MDMT per Fig UCS-66 note (c) = -55°F	

UCS-66 Material Toughness Requirements	
LWN rated MDMT per UCS-66(c)(4) =	-39°F
Material is exempt from impact testing at the Design MDMT of -20°F.	

### Reinforcement Calculations for MAWP

Available reinforcement per UG-37 governs the MAWP of this nozzle.

UG-37 Area Calculation Summary (in <sup>2</sup> )							UG-45 Summary (in)	
For P = 5,010.21 psi @ 200 °F The opening is adequately reinforced							The nozzle passes UG-45	
A required	A available	A <sub>1</sub>	A <sub>2</sub>	A <sub>3</sub>	A <sub>5</sub>	A welds	t <sub>req</sub>	t <sub>min</sub>
15.3347	15.3348	0.1448	4.1275	7.8125	--	3.25	0.5896	1.25

UG-41 Weld Failure Path Analysis Summary
The nozzle is exempt from weld strength calculations per UW-15(b)(1)



UW-16 Weld Sizing Summary			
Weld description	Required weld throat size (in)	Actual weld throat size (in)	Status
Nozzle to shell fillet (Leg <sub>41</sub> )	0.25	1.05	weld size is adequate

#### Reinforcement Calculations for MAP

Available reinforcement per UG-37 governs the MAP of this nozzle.


UG-37 Area Calculation Summary (in <sup>2</sup> )							UG-45 Summary (in)	
For P = 5,010.21 psi @ 70 °F The opening is adequately reinforced							The nozzle passes UG-45	
A required	A available	A <sub>1</sub>	A <sub>2</sub>	A <sub>3</sub>	A <sub>5</sub>	A welds	t <sub>req</sub>	t <sub>min</sub>
15.3347	15.3348	0.1448	4.1275	7.8125	--	3.25	0.5896	1.25

UG-41 Weld Failure Path Analysis Summary	
The nozzle is exempt from weld strength calculations per UW-15(b)(1)	

UW-16 Weld Sizing Summary			
Weld description	Required weld throat size (in)	Actual weld throat size (in)	Status
Nozzle to shell fillet (Leg <sub>41</sub> )	0.25	1.05	weld size is adequate

## GAS OUTLET (N2)

ASME Section VIII Division 1, 2017 Edition



Note: round inside edges per UG-76(c)

### Location and Orientation

Located on	Hemi Head #1
Orientation	0°
End of nozzle to datum line	35.0351"
Calculated as hillside	No
Distance to head center, R	0"
Passes through a Category A joint	No

### Nozzle

Access opening	No
Material specification	SA-105 (II-D p. 18, ln. 19)
Inside diameter, new	3"
Nominal wall thickness	1.125"
Corrosion allowance	0"
Projection available outside vessel, L <sub>pr</sub>	5.13"
Projection available outside vessel to flange face, L <sub>f</sub>	8"
Local vessel minimum thickness	3.1"
Liquid static head included	0.28 psi
Longitudinal joint efficiency	1

### Reinforcing Pad

Material specification	SA-516 70 (II-D p. 18, ln. 33)
Diameter, D <sub>p</sub>	11.25"
Thickness, t <sub>e</sub>	0.625"

Is split	No
<b>Welds</b>	
Inner fillet, Leg <sub>41</sub>	0.75"
Outer fillet, Leg <sub>42</sub>	0.625"
Nozzle to vessel groove weld	1.125"
Pad groove weld	0.625"

ASME B16.5-2013 Flange	
<b>Description</b>	NPS 3 Class 2500 LWN A105
<b>Bolt Material</b>	SA-193 B7 Bolt $\leq 2 \frac{1}{2}$ (II-D p. 388, ln. 32)
<b>Blind included</b>	No
<b>Rated MDMT</b>	-55°F
<b>Liquid static head</b>	0 psi
<b>MAWP rating</b>	5,655 psi @ 200°F
<b>MAP rating</b>	6,170 psi @ 70°F
<b>Hydrotest rating</b>	9,275 psi @ 70°F
<b>PWHT performed</b>	Yes
<b>Impact Tested</b>	No
Notes	
Flange rated MDMT per UCS-66(b)(1)(b) = -55°F (Coincident ratio = 0.8104) Bolts rated MDMT per Fig UCS-66 note (c) = -55°F	

UCS-66 Material Toughness Requirements	
LWN rated MDMT per UCS-66(c)(4) =	-55°F
Material is exempt from impact testing at the Design MDMT of -20°F.	

UCS-66 Material Toughness Requirements Pad	
Governing thickness, $t_g =$	0.625"
Exemption temperature from Fig UCS-66 Curve B =	5 °F
$t_r = 5,000.28 \cdot 24 / (2 \cdot 20,000 \cdot 1 - 0.2 \cdot 5,000.28) =$	3.0771"
Stress ratio = $t_r \cdot E^* / (t_n - c) = 3.0771 \cdot 1 / (3.1 - 0) =$	0.9926
Reduction in MDMT, $T_R$ from Fig UCS-66.1 =	0.7 °F
Reduction in MDMT, $T_{PWHT}$ from UCS-68(c) =	30 °F
MDMT = $\max[\text{MDMT} - T_R - T_{PWHT}, -55] = \max[5 - 0.7 - 30, -55] =$	-25.7 °F
Material is exempt from impact testing at the Design MDMT of -20 °F.	

### Reinforcement Calculations for MAWP

Available reinforcement per UG-37 governs the MAWP of this nozzle.

UG-37 Area Calculation Summary (in <sup>2</sup> )							UG-45 Summary (in)	
For P = 5,011.71 psi @ 200 °F The opening is adequately reinforced							The nozzle passes UG-45	
A required	A available	A <sub>1</sub>	A <sub>2</sub>	A <sub>3</sub>	A <sub>5</sub>	A welds	t <sub>req</sub>	t <sub>min</sub>
9.2529	9.253	0.1326	4.6929	--	3.75	0.6775	0.4424	1.125

UG-41 Weld Failure Path Analysis Summary (lb <sub>f</sub> )				
All failure paths are stronger than the applicable weld loads				
Weld load W	Weld load W <sub>1-1</sub>	Path 1-1 strength	Weld load W <sub>2-2</sub>	Path 2-2 strength
182,406.6	182,408	195,711.4	105,108	224,368.62

UW-16 Weld Sizing Summary			
Weld description	Required weld throat size (in)	Actual weld throat size (in)	Status
Nozzle to pad fillet (Leg <sub>41</sub> )	0.25	0.525	weld size is adequate
Pad to shell fillet (Leg <sub>42</sub> )	0.3125	0.4375	weld size is adequate

## Reinforcement Calculations for MAP

Available reinforcement per UG-37 governs the MAP of this nozzle.


UG-37 Area Calculation Summary (in <sup>2</sup> )							UG-45 Summary (in)	
For P = 5,011.71 psi @ 70 °F The opening is adequately reinforced							The nozzle passes UG-45	
A required	A available	A <sub>1</sub>	A <sub>2</sub>	A <sub>3</sub>	A <sub>5</sub>	A welds	t <sub>req</sub>	t <sub>min</sub>
9.2529	9.253	0.1326	4.6929	--	3.75	0.6775	0.4424	1.125

UG-41 Weld Failure Path Analysis Summary (lb <sub>f</sub> )				
All failure paths are stronger than the applicable weld loads				
Weld load W	Weld load W <sub>1-1</sub>	Path 1-1 strength	Weld load W <sub>2-2</sub>	Path 2-2 strength
182,406.6	182,408	195,711.4	105,108	224,368.62

UW-16 Weld Sizing Summary			
Weld description	Required weld throat size (in)	Actual weld throat size (in)	Status
Nozzle to pad fillet (Leg <sub>41</sub> )	0.25	0.525	weld size is adequate
Pad to shell fillet (Leg <sub>42</sub> )	0.3125	0.4375	weld size is adequate

## DRAIN (N3)

### ASME Section VIII Division 1, 2017 Edition



Note: round inside edges per UG-76(c)

#### Location and Orientation

Located on	Hemi Head #2
Orientation	0°
End of nozzle to datum line	-34.9726"
Calculated as hillside	No
Distance to head center, R	0"
Passes through a Category A joint	No

#### Nozzle

Access opening	No
Material specification	SA-105 (II-D p. 18, ln. 19)
Inside diameter, new	3"
Nominal wall thickness	1.125"
Corrosion allowance	0"
Projection available outside vessel, L <sub>pr</sub>	5.13"
Projection available outside vessel to flange face, L <sub>f</sub>	8"
Local vessel minimum thickness	3.1"
Liquid static head included	2.29 psi
Longitudinal joint efficiency	1

#### Reinforcing Pad

Material specification	SA-516 70 (II-D p. 18, ln. 33)
Diameter, D <sub>p</sub>	11.25"
Thickness, t <sub>e</sub>	0.625"



Is split	No
<b>Welds</b>	
Inner fillet, Leg <sub>41</sub>	0.75"
Outer fillet, Leg <sub>42</sub>	0.625"
Nozzle to vessel groove weld	1.125"
Pad groove weld	0.625"

ASME B16.5-2013 Flange	
<b>Description</b>	NPS 3 Class 2500 LWN A105
<b>Bolt Material</b>	SA-193 B7 Bolt <= 2 1/2 (II-D p. 388, ln. 32)
<b>Blind included</b>	No
<b>Rated MDMT</b>	-55°F
<b>Liquid static head</b>	2.41 psi
<b>MAWP rating</b>	5,655 psi @ 200°F
<b>MAP rating</b>	6,170 psi @ 70°F
<b>Hydrotest rating</b>	9,275 psi @ 70°F
<b>PWHT performed</b>	Yes
<b>Impact Tested</b>	No
Notes	
Flange rated MDMT per UCS-66(b)(1)(b) = -55°F (Coincident ratio = 0.8108) Bolts rated MDMT per Fig UCS-66 note (c) = -55°F	

UCS-66 Material Toughness Requirements	
LWN rated MDMT per UCS-66(c)(4) =	-55°F
Material is exempt from impact testing at the Design MDMT of -20°F.	

UCS-66 Material Toughness Requirements Pad	
Governing thickness, $t_g =$	0.625"
Exemption temperature from Fig UCS-66 Curve B =	5 °F
$t_r = 5,002.29 \times 24 / (2 \times 20,000 \times 1 - 0.2 \times 5,002.29) =$	3.0784"
Stress ratio = $t_r \times E^* / (t_n - c) = 3.0784 \times 1 / (3.1 - 0) =$	0.993
Reduction in MDMT, $T_R$ from Fig UCS-66.1 =	0.7 °F
Reduction in MDMT, $T_{PWHT}$ from UCS-68(c) =	30 °F
MDMT = $\max[\text{MDMT} - T_R - T_{PWHT}, -55] = \max[5 - 0.7 - 30, -55] =$	-25.7 °F
Material is exempt from impact testing at the Design MDMT of -20 °F.	

### Reinforcement Calculations for MAWP

Available reinforcement per UG-37 governs the MAWP of this nozzle.

UG-37 Area Calculation Summary (in <sup>2</sup> )							UG-45 Summary (in)	
For P = 5,011.71 psi @ 200 °F The opening is adequately reinforced							The nozzle passes UG-45	
A required	A available	A <sub>1</sub>	A <sub>2</sub>	A <sub>3</sub>	A <sub>5</sub>	A welds	t <sub>req</sub>	t <sub>min</sub>
9.2529	9.253	0.1326	4.6929	--	3.75	0.6775	0.4424	1.125

UG-41 Weld Failure Path Analysis Summary (lb <sub>f</sub> )				
All failure paths are stronger than the applicable weld loads				
Weld load W	Weld load W <sub>1-1</sub>	Path 1-1 strength	Weld load W <sub>2-2</sub>	Path 2-2 strength
182,406.6	182,408	195,711.4	105,108	224,368.62

UW-16 Weld Sizing Summary			
Weld description	Required weld throat size (in)	Actual weld throat size (in)	Status
Nozzle to pad fillet (Leg <sub>41</sub> )	0.25	0.525	weld size is adequate
Pad to shell fillet (Leg <sub>42</sub> )	0.3125	0.4375	weld size is adequate

## Reinforcement Calculations for MAP

Available reinforcement per UG-37 governs the MAP of this nozzle.


UG-37 Area Calculation Summary (in <sup>2</sup> )							UG-45 Summary (in)	
For P = 5,011.71 psi @ 70 °F The opening is adequately reinforced							The nozzle passes UG-45	
A required	A available	A <sub>1</sub>	A <sub>2</sub>	A <sub>3</sub>	A <sub>5</sub>	A welds	t <sub>req</sub>	t <sub>min</sub>
9.2529	9.253	0.1326	4.6929	--	3.75	0.6775	0.4424	1.125

UG-41 Weld Failure Path Analysis Summary (lb <sub>f</sub> )				
All failure paths are stronger than the applicable weld loads				
Weld load W	Weld load W <sub>1-1</sub>	Path 1-1 strength	Weld load W <sub>2-2</sub>	Path 2-2 strength
182,406.6	182,408	195,711.4	105,108	224,368.62

UW-16 Weld Sizing Summary			
Weld description	Required weld throat size (in)	Actual weld throat size (in)	Status
Nozzle to pad fillet (Leg <sub>41</sub> )	0.25	0.525	weld size is adequate
Pad to shell fillet (Leg <sub>42</sub> )	0.3125	0.4375	weld size is adequate

PSV (N4A)

ASME Section VIII Division 1, 2017 Edition



Note: round inside edges per UG-76(c)

Location and Orientation

Located on	Hemi Head #1
Orientation	225°
End of nozzle to datum line	21.0103"
Calculated as hillside	No
Distance to head center, R	18.48"
Passes through a Category A joint	No

Nozzle

Description	NPS 1 Class 6000 - threaded
Access opening	No
Material specification	SA-105 (II-D p. 18, ln. 19)
Inside diameter, new	1.315"
Nominal wall thickness	0.4675"
Corrosion allowance	0"
Projection available outside vessel, L <sub>pr</sub>	1.563"
Local vessel minimum thickness	3.1"
Liquid static head included	0.52 psi
Longitudinal joint efficiency	1

Welds

Inner fillet, Leg <sub>41</sub>	0.375"
---------------------------------	--------

UCS-66 Material Toughness Requirements Nozzle	
Governing thickness, $t_g =$	0.4675"
Exemption temperature from Fig UCS-66 Curve B =	-10.12°F
$t_r = 5,000.52 * 0.6575 / (20,000 * 1 - 0.6 * 5,000.52) =$	0.1934"
Stress ratio = $t_r * E^* / (t_n - c) = 0.1934 * 1 / (0.4675 - 0) =$	0.4137
Reduction in MDMT, $T_R$ from Fig UCS-66.1 =	84.9°F
Reduction in MDMT, $T_{PWHT}$ from UCS-68(c) =	30°F
MDMT = $\max[MDMT - T_R - T_{PWHT}, -55] = \max[-10.12 - 84.9 - 30, -55] =$	-55°F
Material is exempt from impact testing at the Design MDMT of -20°F.	

### Reinforcement Calculations for MAWP

The vessel wall thickness governs the MAWP of this nozzle.

UG-37 Area Calculation Summary (in <sup>2</sup> )							UG-44 Summary (in)	
For P = 5,036.56 psi @ 200 °F							The nozzle passes UG-44	
A required	A available	A <sub>1</sub>	A <sub>2</sub>	A <sub>3</sub>	A <sub>5</sub>	A welds	t <sub>req</sub>	t <sub>min</sub>
This nozzle is exempt from area calculations per UG-36(c)(3)(a)							0.2574	0.4675

UG-41 Weld Failure Path Analysis Summary
The nozzle is exempt from weld strength calculations per UW-15(b)(2)

UW-16 Weld Sizing Summary			
Weld description	Required weld throat size (in)	Actual weld throat size (in)	Status
Nozzle to shell fillet (Leg <sub>41</sub> )	0.25	0.2625	weld size is adequate

**This opening does not require reinforcement per UG-36(c)(3)(a)**

## Reinforcement Calculations for MAP

The vessel wall thickness governs the MAP of this nozzle.

UG-37 Area Calculation Summary (in <sup>2</sup> )							UG-44 Summary (in)	
For P = 5,036.56 psi @ 70 °F							The nozzle passes UG-44	
A required	A available	A <sub>1</sub>	A <sub>2</sub>	A <sub>3</sub>	A <sub>5</sub>	A welds	t <sub>req</sub>	t <sub>min</sub>
This nozzle is exempt from area calculations per UG-36(c)(3)(a)							0.2574	0.4675

UG-41 Weld Failure Path Analysis Summary	
The nozzle is exempt from weld strength calculations per UW-15(b)(2)	


UW-16 Weld Sizing Summary			
Weld description	Required weld throat size (in)	Actual weld throat size (in)	Status
Nozzle to shell fillet (Leg <sub>41</sub> )	0.25	0.2625	weld size is adequate

**This opening does not require reinforcement per UG-36(c)(3)(a)**



PSV (N4B)

ASME Section VIII Division 1, 2017 Edition



Note: round inside edges per UG-76(c)

Location and Orientation

Located on	Hemi Head #1
Orientation	315°
End of nozzle to datum line	21.0103"
Calculated as hillside	No
Distance to head center, R	18.48"
Passes through a Category A joint	No

Nozzle

Description	NPS 1 Class 6000 - threaded
Access opening	No
Material specification	SA-105 (II-D p. 18, ln. 19)
Inside diameter, new	1.315"
Nominal wall thickness	0.4675"
Corrosion allowance	0"
Projection available outside vessel, L <sub>pr</sub>	1.563"
Local vessel minimum thickness	3.1"
Liquid static head included	0.52 psi
Longitudinal joint efficiency	1

Welds

Inner fillet, Leg <sub>41</sub>	0.375"
---------------------------------	--------

UCS-66 Material Toughness Requirements Nozzle	
Governing thickness, $t_g =$	0.4675"
Exemption temperature from Fig UCS-66 Curve B =	-10.12°F
$t_r = 5,000.52 * 0.6575 / (20,000 * 1 - 0.6 * 5,000.52) =$	0.1934"
Stress ratio = $t_r * E^* / (t_n - c) = 0.1934 * 1 / (0.4675 - 0) =$	0.4137
Reduction in MDMT, $T_R$ from Fig UCS-66.1 =	84.9°F
Reduction in MDMT, $T_{PWHT}$ from UCS-68(c) =	30°F
MDMT = $\max[MDMT - T_R - T_{PWHT}, -55] = \max[-10.12 - 84.9 - 30, -55] =$	-55°F
Material is exempt from impact testing at the Design MDMT of -20°F.	

### Reinforcement Calculations for MAWP

The vessel wall thickness governs the MAWP of this nozzle.

UG-37 Area Calculation Summary (in <sup>2</sup> )							UG-44 Summary (in)	
For P = 5,036.56 psi @ 200 °F							The nozzle passes UG-44	
A required	A available	A <sub>1</sub>	A <sub>2</sub>	A <sub>3</sub>	A <sub>5</sub>	A welds	t <sub>req</sub>	t <sub>min</sub>
This nozzle is exempt from area calculations per UG-36(c)(3)(a)							0.2574	0.4675

UG-41 Weld Failure Path Analysis Summary
The nozzle is exempt from weld strength calculations per UW-15(b)(2)

UW-16 Weld Sizing Summary			
Weld description	Required weld throat size (in)	Actual weld throat size (in)	Status
Nozzle to shell fillet (Leg <sub>41</sub> )	0.25	0.2625	weld size is adequate

**This opening does not require reinforcement per UG-36(c)(3)(a)**

## Reinforcement Calculations for MAP

The vessel wall thickness governs the MAP of this nozzle.


UG-37 Area Calculation Summary (in <sup>2</sup> )							UG-44 Summary (in)	
For P = 5,036.56 psi @ 70 °F							The nozzle passes UG-44	
A required	A available	A <sub>1</sub>	A <sub>2</sub>	A <sub>3</sub>	A <sub>5</sub>	A welds	t <sub>req</sub>	t <sub>min</sub>
This nozzle is exempt from area calculations per UG-36(c)(3)(a)							0.2574	0.4675

UG-41 Weld Failure Path Analysis Summary	
The nozzle is exempt from weld strength calculations per UW-15(b)(2)	

UW-16 Weld Sizing Summary			
Weld description	Required weld throat size (in)	Actual weld throat size (in)	Status
Nozzle to shell fillet (Leg <sub>41</sub> )	0.25	0.2625	weld size is adequate

**This opening does not require reinforcement per UG-36(c)(3)(a)**

## ASME Section VIII Division 1, 2017 Edition



Note: round inside edges per UG-76(c)

## Location and Orientation

Located on	Hemi Head #1
Orientation	270°
End of nozzle to datum line	20.9541"
Calculated as hillside	No
Distance to head center, R	18.5"
Passes through a Category A joint	No

## Nozzle

Description	NPS 0.5 Class 6000 - threaded
Access opening	No
Material specification	SA-105 (II-D p. 18, ln. 19)
Inside diameter, new	0.84"
Nominal wall thickness	0.33"
Corrosion allowance	0"
Projection available outside vessel, L <sub>pr</sub>	1.5"
Local vessel minimum thickness	3.1"
Liquid static head included	0.52 psi
Longitudinal joint efficiency	1

## Welds

Inner fillet, Leg <sub>41</sub>	0.5"
---------------------------------	------

UCS-66 Material Toughness Requirements Nozzle	
Governing thickness, $t_g =$	0.33"
Exemption temperature from Fig UCS-66 Curve B =	-20°F
$t_r = 5,000.52 \cdot 0.42 / (20,000 \cdot 1 - 0.6 \cdot 5,000.52) =$	0.1235"
Stress ratio = $t_r \cdot E^* / (t_n - c) = 0.1235 \cdot 1 / (0.33 - 0) =$	0.3744
Reduction in MDMT, $T_R$ from Fig UCS-66.1 =	113.6°F
Reduction in MDMT, $T_{PWHT}$ from UCS-68(c) =	30°F
MDMT = $\max[MDMT - T_R - T_{PWHT}, -55] = \max[-20 - 113.6 - 30, -55] =$	-55°F
Material is exempt from impact testing at the Design MDMT of -20°F.	

### Reinforcement Calculations for MAWP

The vessel wall thickness governs the MAWP of this nozzle.

UG-37 Area Calculation Summary (in <sup>2</sup> )							UG-44 Summary (in)	
For P = 5,036.56 psi @ 200 °F							The nozzle passes UG-44	
A required	A available	A <sub>1</sub>	A <sub>2</sub>	A <sub>3</sub>	A <sub>5</sub>	A welds	t <sub>req</sub>	t <sub>min</sub>
This nozzle is exempt from area calculations per UG-36(c)(3)(a)							0.1716	0.33

UG-41 Weld Failure Path Analysis Summary
The nozzle is exempt from weld strength calculations per UW-15(b)(2)

UW-16 Weld Sizing Summary			
Weld description	Required weld throat size (in)	Actual weld throat size (in)	Status
Nozzle to shell fillet (Leg <sub>41</sub> )	0.231	0.35	weld size is adequate

**This opening does not require reinforcement per UG-36(c)(3)(a)**

## Reinforcement Calculations for MAP

The vessel wall thickness governs the MAP of this nozzle.

UG-37 Area Calculation Summary (in <sup>2</sup> )							UG-44 Summary (in)	
For P = 5,036.56 psi @ 70 °F							The nozzle passes UG-44	
A required	A available	A <sub>1</sub>	A <sub>2</sub>	A <sub>3</sub>	A <sub>5</sub>	A welds	t <sub>req</sub>	t <sub>min</sub>
This nozzle is exempt from area calculations per UG-36(c)(3)(a)							0.1716	0.33

UG-41 Weld Failure Path Analysis Summary
The nozzle is exempt from weld strength calculations per UW-15(b)(2)

UW-16 Weld Sizing Summary			
Weld description	Required weld throat size (in)	Actual weld throat size (in)	Status
Nozzle to shell fillet (Leg <sub>41</sub> )	0.231	0.35	weld size is adequate

**This opening does not require reinforcement per UG-36(c)(3)(a)**

## Support Lugs #1

Inputs	
Support material	
This support is attached to	Hemi Head #2
Distance from baseplate to datum	-3.875"
Lug allowable stress, $S_b$	50,000 psi
Shell to center of load bearing area, $d$	5"
Lug length, circumferential direction, $L$	8"
Lug attachment fillet weld size	0.75"
Radial/bending lug stiffness ratio	3
Number of support lugs	4
Local Shell	
Outer Diameter	54.2"
Thickness	3.1"
Inner Corrosion	0"
Outer Corrosion	0"
Top Plate	
Width, $W_p$	8"
Thickness, $t_a$	1"
Base Plate	
Width, $b$	10"
Thickness, $t_b$	1"
Load Bearing Width, $L_b$	6.5"
Gusset	
Height, $h$	6.5"
Thickness, $t_g$	0.75"
Separation, $L_g$	4.5"
Anchor Bolts	
Anchor bolt size	0.375" coarse threaded
Anchor bolt material	
Bolt circle, BC	62.5"
Anchor bolts/lug, $n$	1
Anchor bolt allowable stress, $S_b$	20,000 psi
Anchor bolt corrosion allowance	0"



<b>Anchor bolt hole clearance</b>	0.375"
-----------------------------------	--------

Stresses in Shell at Lug Supports													
Condition	Total Weight (lb)	Shear V (lb <sub>f</sub> )	Moment M (lb <sub>f</sub> -ft)	Lug orient	Lug Loading						Stress in Shell (psi)		
					W (lb)	P <sub>r</sub> (lb <sub>f</sub> )	V <sub>L</sub> (lb <sub>f</sub> )	M <sub>L</sub> (lb <sub>f</sub> -ft)	V <sub>c</sub> (lb <sub>f</sub> )	M <sub>c</sub> (lb <sub>f</sub> -ft)	Primary Circ (P <sub>L</sub> )	Primary Long (P <sub>L</sub> )	Combined P <sub>L</sub> +P <sub>b</sub> +Q
Weight, operating Attack angle = 0°	10,016	0	657	0°	2,504	0	2,627	1,094.48	0	0.00	<a href="#">38,745</a>	<a href="#">19,368</a>	<a href="#">38,851</a>
				90°	2,504	0	2,504	1,043.30	0	0.00	38,744	19,368	38,845
				180°	2,504	0	2,627	1,094.48	0	0.00	38,745	19,368	38,851
				270°	2,504	0	2,504	1,043.30	0	0.00	38,744	19,368	38,845
Weight, operating Attack angle = 45°	10,016	0	657	0°	2,504	0	2,591	1,079.49	0	0.00	38,745	19,368	38,850
				90°	2,504	0	2,591	1,079.49	0	0.00	38,745	19,368	38,850
				180°	2,504	0	2,591	1,079.49	0	0.00	38,745	19,368	38,850
				270°	2,504	0	2,591	1,079.49	0	0.00	38,745	19,368	38,850
Weight, operating, new Attack angle = 0°	10,016	0	657	0°	2,504	0	2,627	1,094.48	0	0.00	38,745	19,368	38,851
				90°	2,504	0	2,504	1,043.30	0	0.00	38,744	19,368	38,845
				180°	2,504	0	2,627	1,094.48	0	0.00	38,745	19,368	38,851
				270°	2,504	0	2,504	1,043.30	0	0.00	38,744	19,368	38,845
Weight, operating, new Attack angle = 45°	10,016	0	657	0°	2,504	0	2,591	1,079.49	0	0.00	38,745	19,368	38,850
				90°	2,504	0	2,591	1,079.49	0	0.00	38,745	19,368	38,850
				180°	2,504	0	2,591	1,079.49	0	0.00	38,745	19,368	38,850
				270°	2,504	0	2,591	1,079.49	0	0.00	38,745	19,368	38,850
Weight, empty, new Attack angle = 0°	7,915	0	657	0°	1,979	0	2,102	875.72	0	0.00	-21	-6	-130
				90°	1,979	0	1,979	824.53	0	0.00	-20	-6	-122
				180°	1,979	0	2,102	875.72	0	0.00	-21	-6	-130
				270°	1,979	0	1,979	824.53	0	0.00	-20	-6	-122
Weight, empty, new Attack angle = 45°	7,915	0	657	0°	1,979	0	2,066	860.72	0	0.00	-21	-6	-127
				90°	1,979	0	2,066	860.72	0	0.00	-21	-6	-127
				180°	1,979	0	2,066	860.72	0	0.00	-21	-6	-127
				270°	1,979	0	2,066	860.72	0	0.00	-21	-6	-127

Applied Loads (Weight, operating, Attack angle = 0°, lug orientation = 0°)	
Radial load, P <sub>r</sub>	0 lb <sub>f</sub>
Circumferential moment, M <sub>c</sub>	0 lb <sub>f</sub> -in
Circumferential shear, V <sub>c</sub>	0 lb <sub>f</sub>
Longitudinal moment, M <sub>L</sub>	13,133.8 lb <sub>f</sub> -in
Longitudinal shear, V <sub>L</sub>	2,626.76 lb <sub>f</sub>
Torsion moment, M <sub>t</sub>	0 lb <sub>f</sub> -in
Internal pressure, P	5,001.17 psi
Mean shell radius, R <sub>m</sub>	25.55"
Local shell thickness, T	3.1"
Design factor	3

**Maximum stresses due to the applied loads at the lug edge (includes pressure)**

$$\gamma = R_m / T = 25.55 / 3.1 = 8.2419$$

$$C_1 = 4, C_2 = 4.25 \text{ in}$$

$$\text{Local circumferential pressure stress} = P \cdot R_i / T = 38,719 \text{ psi}$$

$$\text{Local longitudinal pressure stress} = P \cdot R_i / (2 \cdot T) = 19,360 \text{ psi}$$

$$\text{Maximum combined stress } (P_L + P_b + Q) = 38,851 \text{ psi}$$

$$\text{Allowable combined stress } (P_L + P_b + Q) = \pm 3 \cdot S = \pm 60,000 \text{ psi}$$

The maximum combined stress  $(P_L + P_b + Q)$  is within allowable limits.

$$\text{Maximum local primary membrane stress } (P_L) = 38,745 \text{ psi}$$

$$\text{Allowable local primary membrane stress } (P_L) = \pm 1.5 \cdot S = \pm 30,000 \text{ psi}$$

***WRC 107: The local primary membrane stress ( $P_L$ ) is excessive***

Stresses at the lug edge per WRC Bulletin 107										
Figure	value	$\beta$	$A_u$	$A_l$	$B_u$	$B_l$	$C_u$	$C_l$	$D_u$	$D_l$
3C*	1.3856	0.1674	0	0	0	0	0	0	0	0
4C*	1.5191	0.1639	0	0	0	0	0	0	0	0
1C	0.1526	0.1599	0	0	0	0	0	0	0	0
2C-1	0.1187	0.1599	0	0	0	0	0	0	0	0
3A*	0.1922	0.1598	0	0	0	0	0	0	0	0
1A	0.0991	0.1826	0	0	0	0	0	0	0	0
3B*	0.7371	0.163	-26	-26	26	26	0	0	0	0
1B-1	0.0542	0.1639	-106	106	106	-106	0	0	0	0
Pressure stress*			38,719	38,719	38,719	38,719	38,719	38,719	38,719	38,719
Total circumferential stress			38,587	38,799	38,851	38,639	38,719	38,719	38,719	38,719
Primary membrane circumferential stress*			38,693	38,693	38,745	38,745	38,719	38,719	38,719	38,719
3C*	1.3946	0.1639	0	0	0	0	0	0	0	0
4C*	1.5126	0.1674	0	0	0	0	0	0	0	0
1C-1	0.1509	0.1645	0	0	0	0	0	0	0	0
2C	0.1157	0.1645	0	0	0	0	0	0	0	0
4A*	0.2821	0.1598	0	0	0	0	0	0	0	0
2A	0.059	0.1905	0	0	0	0	0	0	0	0
4B*	0.1984	0.163	-8	-8	8	8	0	0	0	0
2B-1	0.0849	0.1765	-154	154	154	-154	0	0	0	0
Pressure stress*			19,360	19,360	19,360	19,360	19,360	19,360	19,360	19,360
Total longitudinal stress			19,198	19,506	19,522	19,214	19,360	19,360	19,360	19,360
Primary membrane longitudinal stress*			19,352	19,352	19,368	19,368	19,360	19,360	19,360	19,360
Shear from $M_t$			0	0	0	0	0	0	0	0
Circ shear from $V_c$			0	0	0	0	0	0	0	0
Long shear from $V_L$			0	0	0	0	-50	-50	50	50
Total Shear stress			0	0	0	0	-50	-50	50	50
Combined stress ( $P_L+P_D+Q$ )			38,587	38,799	38,851	38,639	38,719	38,719	38,719	38,719
* denotes primary stress.										

### Lug top plate required thickness, Bednar 5.2

$$\begin{aligned}t_a &= 0.75 \cdot (V_L \cdot d \cdot L) / (S_b \cdot W_p^2 \cdot h) \\&= 0.75 \cdot (2,626.76 \cdot 5 \cdot 8) / (50,000 \cdot 8^2 \cdot 6.5) \\&= 0.0038 \text{ in}\end{aligned}$$

To prevent buckling  $t_{a(\min)} = (\text{Top plate width})/12 = 0.6667 \text{ in.}$

The top plate thickness of 1 in is adequate.

### Gusset plate required thickness, Bednar 5.2

$$\begin{aligned}S_c &= 37,500 / (1 + (1/37,500) \cdot (h/(0.289 \cdot t_g))^2) \\&= 37,500 / (1 + (1/37,500) \cdot (6.5/(0.289 \cdot 0.75))^2) \\&= 36,622 \text{ psi}\end{aligned}$$

$$\begin{aligned}t_g &= V_L \cdot (3 \cdot d - b) / (S_c \cdot b^2 \cdot (\sin(\alpha))^2) \\&= 2,626.76 \cdot (3 \cdot 5 - 10) / (36,622 \cdot 10^2 \cdot (\sin(72.897))^2) \\&= 0.0039 \text{ in}\end{aligned}$$

The gusset thickness of 0.75 in is adequate.

### Lug base plate required thickness

From Escoe table 4-8 ( $l/b = 2.2222$ )

$$C_x = 0.13144, C_y = -0.125$$

$$\begin{aligned}f_c &= V_L / (L_b \cdot L) \\&= 2,626.76 / (6.5 \cdot 8) \\&= 51 \text{ psi}\end{aligned}$$

$$\begin{aligned}M_x &= C_x \cdot f_c \cdot L_g^2 \\&= 0.13144 \cdot 51 \cdot 4.5^2 \\&= 134.45 \text{ in-lb/in}\end{aligned}$$

$$\begin{aligned}M_y &= C_y \cdot f_c \cdot L_b^2 \\&= -0.125 \cdot 51 \cdot 6.5^2 \\&= -266.78 \text{ in-lb/in}\end{aligned}$$

$$\begin{aligned}M &= \text{Max}[\text{Abs}(M_x), \text{Abs}(M_y)] \\&= \text{Max}[\text{Abs}(134.45), \text{Abs}(-266.78)] \\&= 266.78 \text{ in-lb/in}\end{aligned}$$

$$\begin{aligned}t_b &= \text{Sqr}(6 \cdot M / S_b) \\&= \text{Sqr}(6 \cdot 266.8 / 50,000) \\&= 0.1789 \text{ in}\end{aligned}$$

The base plate thickness of 1 in is adequate.

### Support Lug to Shell Fillet Weld Sizing - Bednar chapters 5.2 and 10.3

Note: continuous welding is assumed for all support lug fillet welds.

$$d_h = t_a + h + t_b$$

$$L_w = 2 \cdot (b + d_h) = 2 \cdot (8 + 8.5) = 33 \text{ in}$$

$$Z_w = b \cdot d_h + d_h^2/3 = 8 \cdot 8.5 + 8.5^2/3 = 92.08 \text{ in}^2$$

$$Z_z = d_h \cdot b + b^2/3 = 8.5 \cdot 8 + 8^2/3 = 89.33 \text{ in}^2$$

$$\text{Shear } f_1 = V_L/L_w = 2,626.76/33 = 80 \text{ lb}_f/\text{in}$$

$$\text{Shear } f_2 = V_c/L_w = 0/33 = 0 \text{ lb}_f/\text{in}$$

$$\text{Bending } f_3 = \text{larger absolute value of } M_L/Z_w \text{ or } M_c/Z_z$$

$$= M_L/Z_w$$

$$= 13,133.8/92.08$$

$$= 142.63 \text{ lb}_f/\text{in}$$

$$\text{Resultant load } f = (f_1^2 + f_2^2 + f_3^2)^{1/2}$$

$$= (79.6^2 + 0^2 + 142.63^2)^{1/2}$$

$$= 163.34 \text{ lb}_f/\text{in}$$

$$\text{Required weld size } w = F/(0.707 \cdot 0.55 \cdot S_a)$$

$$= 163.34/(0.707 \cdot 0.55 \cdot 20,000)$$

$$= 0.021 \text{ in}$$

The support lug fillet weld size of 0.75 in is adequate.

### **Anchor bolts - Weight empty new condition governs**

Tensile loading per lug (1 bolt per lug)

$$R = 48 \cdot M / (N \cdot BC) - W / N$$

$$= 48 \cdot 657.2 / (4 \cdot 62.5) - 7,915.48 / 4$$

$$= -1,852.68 \text{ lb}_f$$

There is no net uplift (R is negative).

0.375" coarse threaded bolts are satisfactory.

**Liquid Level bounded by Hemi Head #2**

ASME Section VIII Division 1, 2017 Edition	
Location from Datum (in)	31.6948
Operating Liquid Specific Gravity	1



## PSV (N4A): FEA Results

Results were generated with the finite element program FE/Pipe#174. Stress results are post-processed in accordance with the rules specified in ASME Section III and ASME Section VIII, Division 2.

Analysis Time Stamp: Wed Feb 06 13:44:41 2019.

- [Model Notes](#)
  - [Load Case Report](#)
  - [Solution Data](#)
  - [ASME Code Stress Output Plots](#)
  - [Stress Results - Notes](#)
  - [ASME Overstressed Areas](#)
  - [Highest Primary Stress Ratios](#)
  - [Highest Secondary Stress Ratios](#)
  - [Highest Fatigue Stress Ratios](#)
  - [Stress Intensification Factors](#)
  - [Allowable Loads](#)
  - [Flexibilities](#)
  - [Graphical Results](#)
- 

Model Notes

Model Notes

Input Echo:

Model Type : Hemispherical Head

Parent Geometry

Parent Outside Diam.	:	54.200 in.
Thickness	:	3.100 in.
Attached Shell Length	:	0.063 in.
Attached Shell Thick	:	7.250 in.
Shell Transition Length:		12.450 in.
Shell Transition SCF	:	0.000 in.
Fillet Along Shell	:	0.375 in.

Parent Properties:

Cold Allowable	:	20000.0 psi
Hot Allowable	:	20000.0 psi
Material ID #2	:	Low Alloy Steel
Ultimate Tensile (Amb)	:	70000.0 psi
Yield Strength (Amb)	:	38000.0 psi
Yield Strength (Hot)	:	34800.0 psi
Elastic Modulus (Amb)	:	29400000.0 psi
Poissons Ratio	:	0.300
Weight Density	:	0.2830E+00 lb./cu.in.

Nozzle Geometry

Nozzle Outside Diam.	:	2.250 in.
Thickness	:	0.468 in.
Length	:	3.090 in.
Nozzle Weld Length	:	0.375 in.
Location perpendicular to the head centerline	:	18.480 in.
Nozzle Tilt Angle	:	42.994 deg.

Nozzle Properties

Cold Allowable	:	20000.0 psi
Hot Allowable	:	20000.0 psi
Material ID #2	:	Low Alloy Steel
Ultimate Tensile (Amb)	:	70000.0 psi
Yield Strength (Amb)	:	36000.0 psi

Yield Strength (Hot) : 33000.0 psi  
Elastic Modulus (Amb) : 29200000.0 psi  
Poissons Ratio : 0.300  
Weight Density : 0.2830E+00 lb./cu.in.

Design Operating Cycles : 0.  
Ambient Temperature (Deg.) : 70.00

Uniform thermal expansion produces no stress in this geometry.  
Any thermal loads will come through operating forces and  
moments applied through the nozzle.

Nozzle Inside Temperature : 200.00 deg.  
Nozzle Outside Temperature : 200.00 deg.  
Vessel Inside Temperature : 200.00 deg.  
Vessel Outside Temperature : 200.00 deg.

Nozzle Pressure : 5000.0 psi  
Vessel Pressure : 5000.0 psi

#### FEA Model Loads:

Loads are given at the Nozzle/Header Junction  
Loads are defined in Global Coordinates

Forces( lb.) Moments (ft-lb)

Load Case	FX	FY	FZ	MX	MY	MZ
WEIGHT:	524.5	582.1	-242.9	-60.0	81.5	-480.0
OPER:	524.5	582.1	-242.9	-60.0	81.5	-480.0

Stresses are NOT averaged.

Vessel Centerline Vector: 0.000 1.000 0.000  
Nozzle Centerline Vector: 0.000 1.000 0.000  
Zero Degree Orientation Vector: 1.000 0.000 0.000

Nozzle Orientation Angle :135.000

### [Table of Contents](#)

#### Load Case Report

FE/Pipe Version 10.0  
Released Nov 2017

Jobname: PSV  
1:44pm FEB 6,2019

\$P

#### Load Case Report

\$X

Inner and outer element temperatures are the same  
throughout the model. No thermal ratcheting  
calculations will be performed.

THE 9 LOAD CASES ANALYZED ARE:

1 WEIGHT ONLY (Wgt Only)

Weight ONLY case run to get the stress range  
between the installed and the operating states.

/----- Loads in Case 1  
Loads due to Weight

2 SUSTAINED (Wgt+Pr)

Sustained case run to satisfy local primary  
membrane and bending stress limits.

/----- Loads in Case 2  
Loads due to Weight  
Pressure Case 1

3 OPERATING

Case run to compute the operating stresses used in  
secondary, peak and range calculations as needed.

/----- Loads in Case 3  
Pressure Case 1  
Loads from (Operating)

4 RANGE (Fatigue Calc Performed)

Case run to get the RANGE of stresses.  
as described in NB-3222.2, 5.5.3.2, 5.5.5.2 or 5.5.6.1.

/----- Combinations in Range Case 4  
Plus Stress Results from CASE 3  
Minus Stress Results from CASE 1

5 Program Generated -- Force Only

Case run to compute sif's and flexibilities.  
/----- Loads in Case 5  
Loads from (Axial)

6 Program Generated -- Force Only

Case run to compute sif's and flexibilities.  
/----- Loads in Case 6  
Loads from (Inplane)

7 Program Generated -- Force Only

Case run to compute sif's and flexibilities.  
/----- Loads in Case 7  
Loads from (Outplane)

8 Program Generated -- Force Only

Case run to compute sif's and flexibilities.  
/----- Loads in Case 8  
Loads from (Torsion)

9 Program Generated -- Force Only

Case run to compute sif's and flexibilities.  
/----- Loads in Case 9  
Pressure Case 1

[Table of Contents](#)

---

Solution Data  
FE/Pipe Version 10.0  
Released Nov 2017

Jobname: PSV  
1:44pm FEB 6, 2019

\$P

## Solution Data

Maximum Solution Row Size = 1158  
 Number of Nodes = 3301  
 Number of Elements = 1108  
 Number of Solution Cases = 8

### Summation of Loads per Case

Case #	FX	FY	FZ
1	524.	-6833.	-243.
2	528.	10247333.	-239.
3	528.	10247333.	-239.
4	-25247.	38297.	-25247.
5	0.	0.	0.
6	0.	0.	0.
7	0.	0.	0.
8	4.	10254166.	4.

### [Table of Contents](#)

---

#### ASME Code Stress Output Plots

FE/Pipe Version 10.0      Jobname: PSV      \$P  
 Released Nov 2017      1:44pm FEB 6, 2019

#### ASME Code Stress Output Plots

\$X

- 1) P1 <(1.5) (S) (SUS,Membrane) Case 2
- 2) Qb <SPS (SUS,Bending) Case 2
- 3) S1+S2+S3 <4S (SUS,S1+S2+S3) Case 2
- 4) P1+Pb+Q <SPS (OPE,Inside) Case 3
- 5) P1+Pb+Q <SPS (OPE,Outside) Case 3
- 6) Membrane <User (OPE,Membrane) Case 3
- 7) Bending <User (OPE,Bending) Case 3
- 8) P1+Pb+Q+F <Sa (SIF,Outside) Case 5
- 9) P1+Pb+Q+F <Sa (SIF,Outside) Case 6
- 10) P1+Pb+Q+F <Sa (SIF,Outside) Case 7
- 11) P1+Pb+Q+F <Sa (SIF,Outside) Case 8
- 12) P1+Pb+Q+F <Sa (SIF,Outside) Case 9
- 13) P1+Pb+Q <SPS (EXP,Inside) Case 4
- 14) P1+Pb+Q <SPS (EXP,Outside) Case 4
- 15) P1+Pb+Q+F <Sa (EXP,Inside) Case 4
- 16) P1+Pb+Q+F <Sa (EXP,Outside) Case 4

### [Table of Contents](#)

---

Stress Results - Notes

FE/Pipe Version 10.0

Jobname: PSV

\$P

Released Nov 2017

1:44pm FEB 6, 2019

Stress Results - Notes

- Results in this analysis were generated using the finite element solution method.
- Using 07-12 ASME Section VIII Division 2
- Use Polished Bar fatigue curve.
- Assume pressure increases all other stresses.
- Assume free end displacements of attached pipe (e.g. thermal loads) are secondary within the limits of nozzle reinforcement.
- Use Equivalent Stress (Von Mises).
- S1+S2+S3 evaluation omitted from operating stress. Include S1+S2+S3 evaluation in primary case evaluation. Assume bending stress not local primary for S1+S2+S3.
- Use local tensor values for averaged and not averaged stresses.

[Table of Contents](#)

---

ASME Overstressed Areas

FE/Pipe Version 10.0

Jobname: PSV

\$P

Released Nov 2017

1:44pm FEB 6, 2019

ASME Overstressed Areas

\$X

\*\*\* NO OVERSTRESSED NODES IN THIS MODEL \*\*\*

[Table of Contents](#)

---

Highest Primary Stress Ratios

FE/Pipe Version 10.0

Jobname: PSV

\$P

Released Nov 2017

1:44pm FEB 6, 2019

Highest Primary Stress Ratios

\$X

Shell Next to Nozzle 1

P1	(1.5) (S)	Primary Membrane Load Case 2
21,265	30,000	Plot Reference:
psi	psi	1) P1 <(1.5) (S) (SUS,Membrane) Case 2

70%

#### Nozzle 1 Next to Shell

P1	(1.5) (S)	Primary Membrane Load Case 2
22,114	30,000	Plot Reference:
psi	psi	1) P1 <(1.5) (S) (SUS,Membrane) Case 2

73%

#### Shell In Nozzle 1 Vicinity

P1	(1.5) (S)	Primary Membrane Load Case 2
21,362	30,000	Plot Reference:
psi	psi	1) P1 <(1.5) (S) (SUS,Membrane) Case 2

71%

#### Nozzle 1

P1	(1.5) (S)	Primary Membrane Load Case 2
9,758	30,000	Plot Reference:
psi	psi	1) P1 <(1.5) (S) (SUS,Membrane) Case 2

32%

### [Table of Contents](#)

#### Highest Secondary Stress Ratios

FE/Pipe Version 10.0	Jobname: PSV	\$P
Released Nov 2017	1:44pm FEB 6,2019	

#### Highest Secondary Stress Ratios \$X

#### Shell Next to Nozzle 1

P1+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 4
30,010	72,800	Plot Reference:
psi	psi	13) P1+Pb+Q <SPS (EXP,Inside) Case 4

41%

#### Nozzle 1 Next to Shell

P1+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 3
52,016	69,000	Plot Reference:
psi	psi	4) P1+Pb+Q <SPS (OPE,Inside) Case 3

75%

#### Shell In Nozzle 1 Vicinity

P1+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 3
---------	-----	---------------------------------------

24,510	72,800	Plot Reference:
psi	psi	4) Pl+Pb+Q <SPS (OPE,Inside) Case 3

33%

#### Nozzle 1

Pl+Pb+Q	SPS	Primary+Secondary (Inner) Load Case 3
14,514	69,000	Plot Reference:
psi	psi	4) Pl+Pb+Q <SPS (OPE,Inside) Case 3

21%

### [Table of Contents](#)

#### Highest Fatigue Stress Ratios

FE/Pipe Version 10.0	Jobname: PSV	\$P
Released Nov 2017	1:44pm FEB 6,2019	

#### Highest Fatigue Stress Ratios

\$X

#### Shell Next to Nozzle 1

Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Inner) Load Case 4
20,256	0.000 Life	Stress Concentration Factor = 1.350
psi	0.011 Stress	Strain Concentration Factor = 1.000
		Cycles Allowed for this Stress = 84,926.
Allowable		"B31" Fatigue Stress Allowable = 50000.0
1,799,215		Mark1 Fatigue Stress Allowable = 245000.0
psi		WRC 474 Mean Cycles to Failure = 147,762.
		WRC 474 99% Probability Cycles = 34,327.
1%		WRC 474 95% Probability Cycles = 47,660.
		BS5500 Allowed Cycles(Curve F) = 30,062.
		Membrane-to-Bending Ratio = 1.771
		Bending-to-PL+PB+Q Ratio = 0.361
		Plot Reference:
		15) Pl+Pb+Q+F <Sa (EXP,Inside) Case 4

#### Nozzle 1 Next to Shell

Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Inner) Load Case 4
33,699	0.000 Life	Stress Concentration Factor = 1.350
psi	0.019 Stress	Strain Concentration Factor = 1.000
		Cycles Allowed for this Stress = 14,236.
Allowable		"B31" Fatigue Stress Allowable = 50000.0
1,786,975		Mark1 Fatigue Stress Allowable = 245000.0
psi		WRC 474 Mean Cycles to Failure = 121,657.
		WRC 474 99% Probability Cycles = 28,263.
1%		WRC 474 95% Probability Cycles = 39,240.
		BS5500 Allowed Cycles(Curve F) = 17,342.
		Membrane-to-Bending Ratio = 0.525
		Bending-to-PL+PB+Q Ratio = 0.656
		Plot Reference:
		15) Pl+Pb+Q+F <Sa (EXP,Inside) Case 4

#### Shell In Nozzle 1 Vicinity

Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Inner) Load Case 4
12,248	0.000 Life	Stress Concentration Factor = 1.000

psi 0.007 Stress Strain Concentration Factor = 1.000  
 Cycles Allowed for this Stress = 1,003,911.  
 Allowable "B31" Fatigue Stress Allowable = 50000.0  
 1,799,215 Markl Fatigue Stress Allowable = 245000.0  
 psi WRC 474 Mean Cycles to Failure = 271,572.  
 WRC 474 99% Probability Cycles = 63,090.  
 0% WRC 474 95% Probability Cycles = 87,593.  
 BS5500 Allowed Cycles (Curve F) = 55,277.  
 Membrane-to-Bending Ratio = 6.423  
 Bending-to-PL+PB+Q Ratio = 0.135  
 Plot Reference:  
 15) Pl+Pb+Q+F <Sa (EXP,Inside) Case 4

#### Nozzle 1

Pl+Pb+Q+F Damage Ratio Primary+Secondary+Peak (Inner) Load Case 4  
 5,965 0.000 Life Stress Concentration Factor = 1.000  
 psi 0.003 Stress Strain Concentration Factor = 1.000  
 Cycles Allowed for this Stress = 1.0000E11  
 Allowable "B31" Fatigue Stress Allowable = 50000.0  
 1,786,975 Markl Fatigue Stress Allowable = 245000.0  
 psi WRC 474 Mean Cycles to Failure = 9,854,857.  
 WRC 474 99% Probability Cycles = 2,289,416.  
 0% WRC 474 95% Probability Cycles = 3,178,612.  
 BS5500 Allowed Cycles (Curve F) = 1,270,589.  
 Membrane-to-Bending Ratio = 1.070  
 Bending-to-PL+PB+Q Ratio = 0.483  
 Plot Reference:  
 15) Pl+Pb+Q+F <Sa (EXP,Inside) Case 4

### [Table of Contents](#)

#### Stress Intensification Factors

FE/Pipe Version 10.0 Jobname: PSV \$P  
 Released Nov 2017 1:44pm FEB 6, 2019

Stress Intensification Factors \$X

#### Branch/Nozzle Sif Summary

	Peak	Primary	Secondary	SSI
Axial :	0.893	1.016	1.322	0.974
Inplane :	0.892	0.809	1.322	0.963
Outplane:	0.889	0.805	1.318	0.973
Torsion :	1.177	0.968	1.744	1.085
Pressure:	0.771	0.489	1.142	0.942

The above stress intensification factors are to be used in a beam-type analysis of the piping system. Inplane, Outplane and Torsional sif's should be used with the matching branch pipe whose diameter and thickness is given below. The axial sif should be used to intensify the axial stress in the branch pipe calculated by F/A. The pressure sif should be used to intensify the nominal pressure stress in the PARENT or HEADER, calculated from PDo/2T. B31 calculations use mean diameters and Section VIII calculations use outside diameters. SSIs are based on peak stress factors and correlated test results.

Pipe OD : 2.250 in.  
 Pipe Thk: 0.468 in.



Z approx: 1.167 cu.in.  
 Z exact : 0.988 cu.in.

(SSI = SIF^x)      Axial    Inpl    Outpl    Tors    Pres  
 SIF/SSI Exponents:   -0.137   1.861   1.848   -0.197   2.754

SIF/SSI exponent based on relationship between primary and peak stress factors from the finite element analysis.

B31.3 Branch Pressure i-factor = 7.071  
 Header Pressure i-factor = 1.635

The B31.3 pressure i-factors should be used with with F/A, where F is the axial force due to pressure, and A is the area of the pipe wall. This is equivalent to finding the pressure stress from (ip) (PD/4T).

B31.3 (Branch)  
 Peak Stress Sif .... 0.000      Axial  
                          1.000      Inplane  
                          1.000      Outplane  
                          1.000      Torsional

B31.1 (Branch)  
 Peak Stress Sif .... 0.000      Axial  
                          1.000      Inplane  
                          1.000      Outplane  
                          1.000      Torsional

WRC 330 (Branch)  
 Peak Stress Sif .... 0.000      Axial  
                          1.000      Inplane  
                          1.500      Outplane  
                          1.000      Torsional

## [Table of Contents](#)

Allowable Loads  
 FE/Pipe Version 10.0      Jobname: PSV      \$P  
 Released Nov 2017      1:44pm    FEB 6,2019

Allowable Loads      \$X

SECONDARY Load Type (Range):	Maximum Individual Occuring	Conservative Simultaneous Occuring	Realistic Simultaneous Occuring
Axial Force (lb. )	136589.	15247.	22870.
Inplane Moment (in. lb.)	51551.	5603.	11886.
Outplane Moment (in. lb.)	51726.	5622.	11927.
Torsional Moment (in. lb.)	39088.	3602.	5403.
Pressure (psi )	6910.47	5000.00	5000.00

PRIMARY Load Type:	Maximum Individual Occuring	Conservative Simultaneous Occuring	Realistic Simultaneous Occuring
Axial Force (lb. )	77325.	8280.	12420.
Inplane Moment (in. lb.)	36622.	2773.	5882.
Outplane Moment (in. lb.)	36797.	2786.	5911.
Torsional Moment (in. lb.)	30599.	3277.	4915.
Pressure (psi )	7024.01	5000.00	5000.00

NOTES:

- 1) Maximum Individual Occuring Loads are the maximum allowed values of the respective loads if all other load components are zero, i.e. the listed axial force may be applied if the inplane, outplane and torsional moments, and the pressure are zero.
- 2) The Conservative Allowable Simultaneous loads are the maximum loads that can be applied simultaneously. A conservative stress combination equation is used that typically produces stresses within 50-70% of the allowable stress.
- 3) The Realistic Allowable Simultaneous loads are the maximum loads that can be applied simultaneously. A more realistic stress combination equation is used based on experience at Paulin Research. Stresses are typically produced within 80-105% of the allowable.
- 4) Secondary allowable loads are limits for expansion and operating piping loads.
- 5) Primary allowable loads are limits for weight, primary and sustained type piping loads.

### [Table of Contents](#)

---

#### Flexibilities

FE/Pipe Version 10.0  
Released Nov 2017

Jobname: PSV  
1:44pm FEB 6,2019

\$P

#### Flexibilities

\$X

The following stiffnesses should be used in a piping, "beam-type" analysis of the intersection. The stiffnesses should be inserted at the surface of the branch/header or nozzle/vessel junction. The general characteristics used for the branch pipe should be:

Outside Diameter = 2.250 in.  
Wall Thickness = 0.468 in.

Axial Translational Stiffness = 32297196. lb./in.

The following stiffness(es) were not generated because of errors in input or because the finite element model is stiffer than the piping model.

Inplane Rotational Stiffness  
Outplane Rotational Stiffness  
Torsional Rotational Stiffness

#### Intersection Flexibility Factors for Branch/Nozzle

Find axial stiffness:  $K = 3EI/(kd)^3$  lb./in.  
Find bending and torsional stiffnesses:  $K = EI/(kd)$  in.lb.per radian.  
The EI product is 0.32671E+08 lb.in.^2  
The value of (d) to use is: 1.783 in..  
The resulting bending stiffness is in units of force x length per radian.

Axial Flexibility Factor (k) = 0.812

### [Table of Contents](#)

## *Finite Element Model*

- [Finite Element Model](#)


### *Area of Discontinuity at Nozzle*

- [1\)  \$PI < \(1.5\)\(S\)\$  \(SUS Membrane\) Case 2](#)
- [2\)  \$Qb < SPS\$  \(SUS Bending\) Case 2](#)
- [3\)  \$S1+S2+S3 < 4S\$  \(SUS  \$S1+S2+S3\$ \) Case 2](#)
- [4\)  \$PI+Pb+Q < SPS\$  \(OPE Inside\) Case 3](#)
- [5\)  \$PI+Pb+Q < SPS\$  \(OPE Outside\) Case 3](#)
- [6\)  \$Membrane < User\$  \(OPE Membrane\) Case 3](#)
- [7\)  \$Bending < User\$  \(OPE Bending\) Case 3](#)
- [13\)  \$PI+Pb+Q < SPS\$  \(EXP Inside\) Case 4](#)
- [14\)  \$PI+Pb+Q < SPS\$  \(EXP Outside\) Case 4](#)
- [15\)  \$PI+Pb+Q+F < Sa\$  \(EXP Inside\) Case 4](#)
- [16\)  \$PI+Pb+Q+F < Sa\$  \(EXP Outside\) Case 4](#)
- [8\)  \$PI+Pb+Q+F < Sa\$  \(SIF Outside\) Case 5](#)
- [9\)  \$PI+Pb+Q+F < Sa\$  \(SIF Outside\) Case 6](#)
- [10\)  \$PI+Pb+Q+F < Sa\$  \(SIF Outside\) Case 7](#)
- [11\)  \$PI+Pb+Q+F < Sa\$  \(SIF Outside\) Case 8](#)
- [12\)  \$PI+Pb+Q+F < Sa\$  \(SIF Outside\) Case 9](#)

### [Tabular Results](#)


---

### Finite Element Model




---


1)  $P1 < (1.5)(S)$  (SUS Membrane) Case 2




2)  $Q_b < SPS$  (SUS Bending) Case 2




3)  $S1+S2+S3 < 45$  (SUS  $S1+S2+S3$ ) Case 2




4)  $P1+Pb+Q < SPS$  (OPE Inside) Case 3




5)  $P1+Pb+Q < SPS$  (OPE Outside) Case 3



6) Membrane < User (OPE Membrane) Case 3




7) Bending < User (OPE Bending) Case 3






13)  $P1+Pb+Q < SPS$  (EXP Inside) Case 4




14)  $P1+Pb+Q < SPS$  (EXP Outside) Case 4







15)  $P1+Pb+Q+F < Sa$  (EXP Inside) Case 4




16)  $P1+Pb+Q+F < Sa$  (EXP Outside) Case 4




8)  $P1+Pb+Q+F < Sa$  (SIF Outside) Case 5




9)  $P1+Pb+Q+F < Sa$  (SIF Outside) Case 6




10)  $P1+Pb+Q+F < Sa$  (SIF Outside) Case 7



11)  $P1+Pb+Q+F < Sa$  (SIF Outside) Case 8



12)  $P1+Pb+Q+F < Sa$  (SIF Outside) Case 9



## P.I. (N5): FEA Results

Results were generated with the finite element program FE/Pipe&#174. Stress results are post-processed in accordance with the rules specified in ASME Section III and ASME Section VIII, Division 2.

Analysis Time Stamp: Wed Feb 06 13:44:45 2019.

- [Model Notes](#)
  - [Load Case Report](#)
  - [Solution Data](#)
  - [ASME Code Stress Output Plots](#)
  - [Stress Results - Notes](#)
  - [ASME Overstressed Areas](#)
  - [Highest Primary Stress Ratios](#)
  - [Highest Secondary Stress Ratios](#)
  - [Highest Fatigue Stress Ratios](#)
  - [Stress Intensification Factors](#)
  - [Allowable Loads](#)
  - [Flexibilities](#)
  - [Graphical Results](#)
- 

Model Notes

Model Notes

Input Echo:

Model Type : Hemispherical Head

Parent Geometry

Parent Outside Diam.	:	54.200 in.
Thickness	:	3.100 in.
Attached Shell Length	:	0.063 in.
Attached Shell Thick	:	7.250 in.
Shell Transition Length:		12.450 in.
Shell Transition SCF	:	0.000 in.
Fillet Along Shell	:	0.500 in.

Parent Properties:

Cold Allowable	:	20000.0 psi
Hot Allowable	:	20000.0 psi
Material ID #2	:	Low Alloy Steel
Ultimate Tensile (Amb)	:	70000.0 psi
Yield Strength (Amb)	:	38000.0 psi
Yield Strength (Hot)	:	34800.0 psi
Elastic Modulus (Amb)	:	29400000.0 psi
Poissons Ratio	:	0.300
Weight Density	:	0.2830E+00 lb./cu.in.

Nozzle Geometry

Nozzle Outside Diam.	:	1.500 in.
Thickness	:	0.330 in.
Length	:	3.040 in.
Nozzle Weld Length	:	0.500 in.
Location perpendicular to the head centerline	:	18.500 in.
Nozzle Tilt Angle	:	43.052 deg.

Nozzle Properties

Cold Allowable	:	20000.0 psi
Hot Allowable	:	20000.0 psi
Material ID #2	:	Low Alloy Steel
Ultimate Tensile (Amb)	:	70000.0 psi
Yield Strength (Amb)	:	36000.0 psi

Yield Strength (Hot) : 33000.0 psi  
Elastic Modulus (Amb) : 29200000.0 psi  
Poissons Ratio : 0.300  
Weight Density : 0.2830E+00 lb./cu.in.

Design Operating Cycles : 0.  
Ambient Temperature (Deg.) : 70.00

Uniform thermal expansion produces no stress in this geometry.  
Any thermal loads will come through operating forces and  
moments applied through the nozzle.

Nozzle Inside Temperature : 200.00 deg.  
Nozzle Outside Temperature : 200.00 deg.  
Vessel Inside Temperature : 200.00 deg.  
Vessel Outside Temperature : 200.00 deg.

Nozzle Pressure : 5000.0 psi  
Vessel Pressure : 5000.0 psi

#### FEA Model Loads:

Loads are given at the Nozzle/Header Junction  
Loads are defined in Global Coordinates

Forces( lb.) Moments (ft-lb)

Load Case	FX	FY	FZ	MX	MY	MZ
OPER:	542.0	581.9	198.1	298.9	79.8	-383.4

Stresses are NOT averaged.

Vessel Centerline Vector: 0.000 1.000 0.000  
Nozzle Centerline Vector: 0.000 1.000 0.000  
Zero Degree Orientation Vector: 1.000 0.000 0.000

Nozzle Orientation Angle : 90.000

### [Table of Contents](#)

#### Load Case Report

FE/Pipe Version 10.0  
Released Nov 2017

Jobname: PI  
1:44pm FEB 6,2019

\$P

#### Load Case Report

\$X

Inner and outer element temperatures are the same  
throughout the model. No thermal ratcheting  
calculations will be performed.

THE 9 LOAD CASES ANALYZED ARE:

#### 1 WEIGHT ONLY (Wgt Only)

Weight ONLY case run to get the stress range  
between the installed and the operating states.

/----- Loads in Case 1  
Loads due to Weight

#### 2 SUSTAINED (Wgt+Pr)

Sustained case run to satisfy local primary  
membrane and bending stress limits.

/----- Loads in Case 2  
Loads due to Weight  
Pressure Case 1

3 OPERATING

Case run to compute the operating stresses used in  
secondary, peak and range calculations as needed.

/----- Loads in Case 3  
Pressure Case 1  
Loads from (Operating)

4 RANGE (Fatigue Calc Performed)

Case run to get the RANGE of stresses.  
as described in NB-3222.2, 5.5.3.2, 5.5.5.2 or 5.5.6.1.

/----- Combinations in Range Case 4  
Plus Stress Results from CASE 3  
Minus Stress Results from CASE 1

5 Program Generated -- Force Only

Case run to compute sif's and flexibilities.  
/----- Loads in Case 5  
Loads from (Axial)

6 Program Generated -- Force Only

Case run to compute sif's and flexibilities.  
/----- Loads in Case 6  
Loads from (Inplane)

7 Program Generated -- Force Only

Case run to compute sif's and flexibilities.  
/----- Loads in Case 7  
Loads from (Outplane)

8 Program Generated -- Force Only

Case run to compute sif's and flexibilities.  
/----- Loads in Case 8  
Loads from (Torsion)

9 Program Generated -- Force Only

Case run to compute sif's and flexibilities.  
/----- Loads in Case 9  
Pressure Case 1

---

[Table of Contents](#)

Solution Data  
FE/Pipe Version 10.0  
Released Nov 2017

Jobname: PI  
1:44pm FEB 6, 2019

\$P

Solution Data

Maximum Solution Row Size = 1326  
 Number of Nodes = 3313  
 Number of Elements = 1076  
 Number of Solution Cases = 8

#### Summation of Loads per Case

Case #	FX	FY	FZ
1	0.	-4538.	0.
2	4.	6216518.	-8458247.
3	546.	6217100.	-8458048.
4	0.	17727.	-16561.
5	0.	0.	0.
6	0.	0.	0.
7	0.	0.	0.
8	4.	6221056.	-8458247.

#### [Table of Contents](#)

---

#### ASME Code Stress Output Plots

FE/Pipe Version 10.0      Jobname: PI      \$P  
 Released Nov 2017      1:44pm    FEB 6, 2019

#### ASME Code Stress Output Plots

\$X

- 1) P1 <(1.5) (S) (SUS,Membrane) Case 2
- 2) Qb <SPS (SUS,Bending) Case 2
- 3) S1+S2+S3 <4S (SUS,S1+S2+S3) Case 2
- 4) P1+Pb+Q <SPS (OPE,Inside) Case 3
- 5) P1+Pb+Q <SPS (OPE,Outside) Case 3
- 6) Membrane <User (OPE,Membrane) Case 3
- 7) Bending <User (OPE,Bending) Case 3
- 8) P1+Pb+Q+F <Sa (SIF,Outside) Case 5
- 9) P1+Pb+Q+F <Sa (SIF,Outside) Case 6
- 10) P1+Pb+Q+F <Sa (SIF,Outside) Case 7
- 11) P1+Pb+Q+F <Sa (SIF,Outside) Case 8
- 12) P1+Pb+Q+F <Sa (SIF,Outside) Case 9
- 13) P1+Pb+Q <SPS (EXP,Inside) Case 4
- 14) P1+Pb+Q <SPS (EXP,Outside) Case 4
- 15) P1+Pb+Q+F <Sa (EXP,Inside) Case 4
- 16) P1+Pb+Q+F <Sa (EXP,Outside) Case 4

#### [Table of Contents](#)

---



#### Stress Results - Notes

FE/Pipe Version 10.0

Jobname: PI

\$P

Released Nov 2017

1:44pm FEB 6, 2019

#### Stress Results - Notes

- Results in this analysis were generated using the finite element solution method.
- Using 07-12 ASME Section VIII Division 2
- Use Polished Bar fatigue curve.  
Assume pressure increases all other stresses.
- Assume free end displacements of attached pipe (e.g. thermal loads) are secondary within the limits of nozzle reinforcement.
- Use Equivalent Stress (Von Mises).
- S1+S2+S3 evaluation omitted from operating stress.  
Include S1+S2+S3 evaluation in primary case evaluation.  
Assume bending stress not local primary for S1+S2+S3.
- Use local tensor values for averaged and not averaged stresses.

#### [Table of Contents](#)

---

#### ASME Overstressed Areas

FE/Pipe Version 10.0

Jobname: PI

\$P

Released Nov 2017

1:44pm FEB 6, 2019

#### ASME Overstressed Areas

\$X

\*\*\* NO OVERSTRESSED NODES IN THIS MODEL \*\*\*

#### [Table of Contents](#)

---

#### Highest Primary Stress Ratios

FE/Pipe Version 10.0

Jobname: PI

\$P

Released Nov 2017

1:44pm FEB 6, 2019

#### Highest Primary Stress Ratios

\$X

#### Shell Next to Nozzle 1

P1	(1.5) (S)	Primary Membrane Load Case 2
21,170	30,000	Plot Reference:

psi                      psi                      1) P1 <(1.5) (S) (SUS,Membrane) Case 2  
70%

Nozzle 1 Next to Shell

P1                      (1.5) (S)                      Primary Membrane Load Case 2  
24,960                      30,000                      Plot Reference:  
psi                      psi                      1) P1 <(1.5) (S) (SUS,Membrane) Case 2  
83%

Nozzle 1

P1                      (1.5) (S)                      Primary Membrane Load Case 2  
7,909                      30,000                      Plot Reference:  
psi                      psi                      1) P1 <(1.5) (S) (SUS,Membrane) Case 2  
26%

[Table of Contents](#)

---

Highest Secondary Stress Ratios

FE/Pipe Version 10.0                      Jobname: PI                      \$P  
Released Nov 2017                      1:44pm                      FEB 6,2019

Highest Secondary Stress Ratios                      \$X

Shell Next to Nozzle 1

P1+Pb+Q                      SPS                      Primary+Secondary (Inner) Load Case 4  
26,927                      72,800                      Plot Reference:  
psi                      psi                      13) P1+Pb+Q <SPS (EXP,Inside) Case 4  
36%

Nozzle 1 Next to Shell

P1+Pb+Q                      SPS                      Primary+Secondary (Inner) Load Case 4  
63,007                      69,000                      Plot Reference:  
psi                      psi                      13) P1+Pb+Q <SPS (EXP,Inside) Case 4  
91%

Nozzle 1

P1+Pb+Q                      SPS                      Primary+Secondary (Outer) Load Case 4  
22,318                      69,000                      Plot Reference:  
psi                      psi                      14) P1+Pb+Q <SPS (EXP,Outside) Case 4  
32%

[Table of Contents](#)

---

Highest Fatigue Stress Ratios

FE/Pipe Version 10.0                      Jobname: PI                      \$P

## Highest Fatigue Stress Ratios

\$X

## Shell Next to Nozzle 1

Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Inner) Load Case 4
18,176	0.000 Life	Stress Concentration Factor = 1.350
psi	0.010 Stress	Strain Concentration Factor = 1.000
		Cycles Allowed for this Stress = 131,241.
Allowable		"B31" Fatigue Stress Allowable = 50000.0
1,799,215		Mark1 Fatigue Stress Allowable = 245000.0
psi		WRC 474 Mean Cycles to Failure = 205,049.
		WRC 474 99% Probability Cycles = 47,636.
1%		WRC 474 95% Probability Cycles = 66,137.
		BS5500 Allowed Cycles(Curve F) = 41,615.
		Membrane-to-Bending Ratio = 2.502
		Bending-to-PL+PB+Q Ratio = 0.286
		Plot Reference:
		15) Pl+Pb+Q+F <Sa (EXP,Inside) Case 4

## Nozzle 1 Next to Shell

Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Inner) Load Case 4
42,530	0.000 Life	Stress Concentration Factor = 1.350
psi	0.024 Stress	Strain Concentration Factor = 1.000
		Cycles Allowed for this Stress = 6,608.
Allowable		"B31" Fatigue Stress Allowable = 50000.0
1,786,975		Mark1 Fatigue Stress Allowable = 245000.0
psi		WRC 474 Mean Cycles to Failure = 72,561.
		WRC 474 99% Probability Cycles = 16,857.
2%		WRC 474 95% Probability Cycles = 23,404.
		BS5500 Allowed Cycles(Curve F) = 8,627.
		Membrane-to-Bending Ratio = 0.707
		Bending-to-PL+PB+Q Ratio = 0.586
		Plot Reference:
		15) Pl+Pb+Q+F <Sa (EXP,Inside) Case 4

## Nozzle 1

Pl+Pb+Q+F	Damage Ratio	Primary+Secondary+Peak (Outer) Load Case 4
11,159	0.000 Life	Stress Concentration Factor = 1.000
psi	0.006 Stress	Strain Concentration Factor = 1.000
		Cycles Allowed for this Stress = 5,310,248.
Allowable		"B31" Fatigue Stress Allowable = 50000.0
1,786,975		Mark1 Fatigue Stress Allowable = 245000.0
psi		WRC 474 Mean Cycles to Failure = 1,692,902.
		WRC 474 99% Probability Cycles = 393,284.
0%		WRC 474 95% Probability Cycles = 546,033.
		BS5500 Allowed Cycles(Curve F) = 194,117.
		Membrane-to-Bending Ratio = 4.142
		Bending-to-PL+PB+Q Ratio = 0.194
		Plot Reference:
		16) Pl+Pb+Q+F <Sa (EXP,Outside) Case 4

[Table of Contents](#)

## Stress Intensification Factors

FE/Pipe Version 10.0

Jobname: PI

\$P

Released Nov 2017

1:44pm FEB 6,2019

## Stress Intensification Factors

\$X

## Branch/Nozzle Sif Summary

	Peak	Primary	Secondary	SSI
Axial :	0.788	1.009	1.167	0.947
Inplane :	0.812	0.794	1.202	0.933
Outplane:	0.797	0.789	1.180	0.949
Torsion :	1.120	0.980	1.660	1.058
Pressure:	0.786	0.571	1.165	0.946

The above stress intensification factors are to be used in a beam-type analysis of the piping system. Inplane, Outplane and Torsional sif's should be used with the matching branch pipe whose diameter and thickness is given below. The axial sif should be used to intensify the axial stress in the branch pipe calculated by  $F/A$ . The pressure sif should be used to intensify the nominal pressure stress in the PARENT or HEADER, calculated from  $PDo/2T$ . B31 calculations use mean diameters and Section VIII calculations use outside diameters. SSIs are based on peak stress factors and correlated test results.

Pipe OD : 1.500 in.  
 Pipe Thk: 0.330 in.  
 Z approx: 0.355 cu.in.  
 Z exact : 0.299 cu.in.

(SSI = SIF <sup>x</sup> )	Axial	Inpl	Outpl	Tors	Pres
SIF/SSI Exponents:	-0.038	1.105	1.040	-0.175	2.327

SIF/SSI exponent based on relationship between primary and peak stress factors from the finite element analysis.

B31.3 Branch Pressure i-factor = 7.753  
 Header Pressure i-factor = 1.668

The B31.3 pressure i-factors should be used with with  $F/A$ , where F is the axial force due to pressure, and A is the area of the pipe wall. This is equivalent to finding the pressure stress from (ip)  $(PD/4T)$ .

B31.3 (Branch)  
 Peak Stress Sif .... 0.000 Axial  
                                   1.000 Inplane  
                                   1.000 Outplane  
                                   1.000 Torsional

B31.1 (Branch)  
 Peak Stress Sif .... 0.000 Axial  
                                   1.000 Inplane  
                                   1.000 Outplane  
                                   1.000 Torsional

WRC 330 (Branch)  
 Peak Stress Sif .... 0.000 Axial  
                                   1.000 Inplane  
                                   1.500 Outplane  
                                   1.000 Torsional

[Table of Contents](#)

## Allowable Loads

\$X

SECONDARY Load Type (Range):		Maximum Individual Occuring	Conservative Simultaneous Occuring	Realistic Simultaneous Occuring
Axial Force	(lb. )	71722.	6792.	10188.
Inplane Moment	(in. lb.)	17143.	1870.	3967.
Outplane Moment	(in. lb.)	17465.	1905.	4042.
Torsional Moment	(in. lb.)	12421.	1086.	1629.
Pressure	(psi )	6777.45	5000.00	5000.00

PRIMARY Load Type:		Maximum Individual Occuring	Conservative Simultaneous Occuring	Realistic Simultaneous Occuring
Axial Force	(lb. )	36064.	2018.	3027.
Inplane Moment	(in. lb.)	11288.	447.	948.
Outplane Moment	(in. lb.)	11354.	450.	954.
Torsional Moment	(in. lb.)	9143.	512.	767.
Pressure	(psi )	6008.77	5000.00	5000.00

## NOTES:

- 1) Maximum Individual Occuring Loads are the maximum allowed values of the respective loads if all other load components are zero, i.e. the listed axial force may be applied if the inplane, outplane and torsional moments, and the pressure are zero.
- 2) The Conservative Allowable Simultaneous loads are the maximum loads that can be applied simultaneously. A conservative stress combination equation is used that typically produces stresses within 50-70% of the allowable stress.
- 3) The Realistic Allowable Simultaneous loads are the maximum loads that can be applied simultaneously. A more realistic stress combination equation is used based on experience at Paulin Research. Stresses are typically produced within 80-105% of the allowable.
- 4) Secondary allowable loads are limits for expansion and operating piping loads.
- 5) Primary allowable loads are limits for weight, primary and sustained type piping loads.

[Table of Contents](#)


---

## Flexibilities

FE/Pipe Version 10.0  
Released Nov 2017

Jobname: PI  
1:44pm FEB 6,2019

\$P

## Flexibilities

\$X

The following stiffnesses should be used in a piping,

"beam-type" analysis of the intersection. The stiffnesses should be inserted at the surface of the branch/header or nozzle/vessel junction. The general characteristics used for the branch pipe should be:

Outside Diameter = 1.500 in.  
Wall Thickness = 0.330 in.

Axial Translational Stiffness = 259963600. lb./in.

The following stiffness(es) were not generated because of errors in input or because the finite element model is stiffer than the piping model.

Inplane Rotational Stiffness  
Outplane Rotational Stiffness  
Torsional Rotational Stiffness

Intersection Flexibility Factors for Branch/Nozzle

Find axial stiffness:  $K = 3EI/(kd)^3$  lb./in.  
Find bending and torsional stiffnesses:  $K = EI/(kd)$  in.lb.per radian.  
The EI product is 0.65875E+07 lb.in.^2  
The value of (d) to use is: 1.170 in..  
The resulting bending stiffness is in units of force x length per radian.

Axial Flexibility Factor (k) = 0.362

[Table of Contents](#)

## *Finite Element Model*

- [Finite Element Model](#)


### *Area of Discontinuity at Nozzle*

- [1\)  \$PI < \(1.5\)\(S\)\$  \(SUS Membrane\) Case 2](#)
- [2\)  \$Qb < SPS\$  \(SUS Bending\) Case 2](#)
- [3\)  \$S1+S2+S3 < 4S\$  \(SUS  \$S1+S2+S3\$ \) Case 2](#)
- [4\)  \$PI+Pb+Q < SPS\$  \(OPE Inside\) Case 3](#)
- [5\)  \$PI+Pb+Q < SPS\$  \(OPE Outside\) Case 3](#)
- [6\)  \$Membrane < User\$  \(OPE Membrane\) Case 3](#)
- [7\)  \$Bending < User\$  \(OPE Bending\) Case 3](#)
- [13\)  \$PI+Pb+Q < SPS\$  \(EXP Inside\) Case 4](#)
- [14\)  \$PI+Pb+Q < SPS\$  \(EXP Outside\) Case 4](#)
- [15\)  \$PI+Pb+Q+F < Sa\$  \(EXP Inside\) Case 4](#)
- [16\)  \$PI+Pb+Q+F < Sa\$  \(EXP Outside\) Case 4](#)
- [8\)  \$PI+Pb+Q+F < Sa\$  \(SIF Outside\) Case 5](#)
- [9\)  \$PI+Pb+Q+F < Sa\$  \(SIF Outside\) Case 6](#)
- [10\)  \$PI+Pb+Q+F < Sa\$  \(SIF Outside\) Case 7](#)
- [11\)  \$PI+Pb+Q+F < Sa\$  \(SIF Outside\) Case 8](#)
- [12\)  \$PI+Pb+Q+F < Sa\$  \(SIF Outside\) Case 9](#)

### [Tabular Results](#)


---

## Finite Element Model




---

1)  $P1 < (1.5)(S)$  (SUS Membrane) Case 2







2)  $Q_b < SPS$  (SUS Bending) Case 2




3)  $S1+S2+S3 < 45$  (SUS  $S1+S2+S3$ ) Case 2




4)  $P1+Pb+Q < SPS$  (OPE Inside) Case 3




5)  $P1+Pb+Q < SPS$  (OPE Outside) Case 3




6) Membrane < User (OPE Membrane) Case 3




7) Bending < User (OPE Bending) Case 3




13)  $P1+Pb+Q < SPS$  (EXP Inside) Case 4




14)  $P1+Pb+Q < SPS$  (EXP Outside) Case 4




15)  $P1+Pb+Q+F < Sa$  (EXP Inside) Case 4




16)  $P1+Pb+Q+F < Sa$  (EXP Outside) Case 4



8)  $P1+Pb+Q+F < Sa$  (SIF Outside) Case 5




9)  $P1+Pb+Q+F < Sa$  (SIF Outside) Case 6







10)  $P1+Pb+Q+F < Sa$  (SIF Outside) Case 7



11)  $P1+Pb+Q+F < Sa$  (SIF Outside) Case 8




12)  $P1+Pb+Q+F < Sa$  (SIF Outside) Case 9






# **Drawings**



NOTES		WELD PROC.	
- PREHEAT TO MIN. 200°F PRIOR TO WELDING		WELD JOINT	PROCEDURE
- Production Impacts @ -20°F Required		NOZZLES	SFI-3-4P
		GIRTH SEAM	SFI-3-4PI
		EXTERNALS	SFI-3-4P
		INTERNALS	SFI-3-4P
			SEE THIS SHT
VESSEL SPECIFICATIONS			
JOB NO: 300164-01,02 , 300165-01-> 300167-01	WEIGHT: 12,000 LBS		
SERIALNO: SFI-48IDX5K-XXX	HYDRO PRESS: 6,500 PSI		
NATIONAL BD NO.: TBD	X-RAY: LG SEAM - N/A		
PAINT: YES	GIRTH SM - 100% PER SFI		
REMARKS: NONE	PWHT: YES		
MDMT: -20°F	CA: 0"		
CODE: ASME SEC. VIII DIV. 1 2017 EDITION			



NOZZLE SCHEDULE													
ITEM	QTY	SERVICE	SIZE	RAT'G	TYPE	MATR'L	BORE	BOM #	PROJECTION O.S.	I.S.	NOZZLE NECK O.D.	WALL	MATR'L
N1	1	INLET	4"	2500#	RTJLWN	-	4"	4	8"	3-1/2"	6.50"	1.25"	SA-105
N2	1	GAS OUTLET	3"	2500#	RTJLWN	-	3"	3.7	8"	-	5.25"	1.125"	SA-105
N3	1	DUMP	3"	2500#	RTJLWN	-	3"	3.7	8"	-	5.25"	1.125"	SA-105
N4A, N4B	1	PSV	1"	6M	TRDLET	SA-105	1.141"	18	1.563"	-	-	-	-
N5	1	P.I.	1/2"	6M	TRDLET	SA-105	0.703	8	1.25"	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-	-	-

REVISIONS			
NO.	DESCRIPTION	DATE	NO.
0	FOR APPROVAL	2/8/17	6C
1	UPDATED LWN O.D. AND WALL DIMENSIONS	2/28/17	
2	UPDATED WELD FIG. C	4/3/17	6D
3	BM#104,113,120 lengths updated	5/30/17	
4	N2 NOZ NECK LENGTH INCREASED BY 1"	8/21/2017	6E
5	SKID UPDATED- HEAD THK. 3.75", DESIGN CODE 2017, CALCS UPDATED	12/18/2017	
5A	HEAD THK. CHANGED TO 3.625, PSV SET UP: 2 X 1" PSVs, WELDS UPDATED	2/12/2018	
6A	Noz schedule Table modified, Weld Detail Block Updated	3/9/2018	

CERTIFIED BY

SYNERGY FABRICATION, INC.  
1432 E. DEVITT ST.  
FORT WORTH, TX 76119

M.A.W.P.

5,000 PSIG @ 200 °F

M.D.M.T.

-20°F @ 5,000 PSIG

ASME

SERIAL

SFI-48IDX5K-XXX

YEAR

2019

U

W

HT

RT-1

DRAWN BY

Kevin McFarland

DRAWING NO.

SFI-48IDX5K-XXX

APPROVED FOR CONSTRUCTION BY:

1 / 3 0 / 2 0 1 9

FOR SM ENERGY UNITS

SCALE

N.T.S.

DRAWING SIZE

B

SHEET

1

REV

6E

NOTE: FOR BORES AND HOLE LOCATIONS SEE SHEET 5

APPROVED FOR CONSTRUCTION BY:

1 / 3 0 / 2 0 1 9

FOR SM ENERGY UNITS

SCALE

N.T.S.

DRAWING SIZE

B


SHEET

1

REV

6E

BOM Table				
MARK	QTY	IMPACT	DESCRIPTION	LENGTH
1	1	YES, -20F	PLATE- 48" I.D. x 3.625" NOM. (3.1" Min.), Full Hemi, 22° O.S. Bevel	
2	1	YES, -20F	PLATE- 48" I.D. x 3.625" NOM. (3.1" Min.), Full Hemi, 22° O.S. Bevel	
3	2		FLANGE, RTJ, LWN, 3" ANSI CL2500 x 12" Lg. (CUT TO DETAIL)	8"
4	1		FLANGE, RTJ, LWN, 4" ANSI CL2500 x 21" Lg.	
5	1		INTERNAL, 0.375 PUNCH PLT, 1/2 DIA. @ 1 CTRS, SEE SHT 2	
6	1		INTERNAL, 1.50" THK. X 24" RAD., SEE DETAIL	
7	2		REPAD: PLATE- 5/8" THK. X 11-1/2 O.D. X 5.750 I.D., Match to Heads, see Detail	
8	1		THREAD-O-LET 1/2" NPT on 52", 6M C.S. A-105	
11	2		MEDIUM LIFTING LUG, PHOENIX, P/N: 2-899-MLL	
10	8		PLATE-3/4 X 7 1/2" X 6 1/2" CUT TO DETAIL	
11	4		PLATE-3/4 X 9 5/16" X 8" - CUT TO DETAIL	
12	4		PLATE-3/4 X 7 5/16" X 8" CUT TO DETAIL	
13	4		W6X20 - 4'-6" LONG	4'-6"
14	1		STANDARD N.P. BRACKET	
15	2		TAYLOR 1" 8200 THREADED VALVE - (ORIFICE D), P/N = 82D9341315, Set @ 5000PSI	
16	2		VALVE, 1/4" M x F Needle, Balon P/N: N263-MF	
17	2		Valve 1" FP 5000psi, KF Model# 05050-11911, Series CXH Floating Ball Valve, CS/C/Delrin/Buna/Handle	
18	2		THREAD-O-LET 1" NPT ON 48" OD, 6M C.S. A-105	
19	6		NIPPLE - 1" Sch XXH (0.358" Wall) Nipple	3"
20	2		NIPPLE-1" Sch 80 (0.179" Wall) Nipple	3"
21	2		TEE, 1" THREADED, CLASS 6000	
22	2		BUSHING- 1" x 1/4" 6M THD x THD Bushing, SA-105	
23	2		PLUG- 1/4" 6000# Hex Plug	
24	2		YELLOW RAIN CAP, 1"	
25	2		Nipple- 1" Sch 80 (0.179" Wall)	6"
26	2		ELL, 45°, 1" CLASS 6000 THREADED, SA-234 WPC OR SA-105	
27	2		ELBOW, THREADED, 90, 1" CLASS 3000, FEMALE	
28	2		U BOLT - 3/8" DIAM. FITS 1" PIPE W/ 2 HEX NUTS AND RUBBER CUSHION (PAD)	



**INTERNAL PUNCH PLATE**  
(1) REQUIRED

**TOP LUG PLATE**  
(4) REQUIRED

**BOTTOM LUG PLATE**  
(4) REQUIRED

**GUSSET PLATE**  
(8) REQUIRED


**INTERNAL BAFFLE PLATE**  
(1) REQUIRED


**GAS OUT / DUMP NOZZLE DETAIL**  
(2) REQUIRED PER UNIT






**DETAIL D**  
**TYPICAL NOZZLE BEVEL DETAIL**

SHOP NOTE: SEE SHEET ONE FOR BOM# DESCRIPTION

 SYNERGY FABRICATION, INC. 1432 E. DEVITT ST. FORT WORTH, TX 76119		
TITLE: 48" ID -5K SPHERICAL Sand Separator		
DWG. NO. SFI-48IDX5K-XXX		REV 6E
DRAWN KM 2/8/2017	CHECKED MS 5/30/2017	APPR. MS 5/30/2017
DRAWING SIZE B	REV. DATE 1/30/2019	SHT 2 OF 5







 SYNERGY FABRICATION, INC. 1432 E. DEVITT ST. FORT WORTH, TX 76119		
<b>TITLE:</b> 48" ID -5K SPHERICAL Sand Separator		
<b>DWG. NO.</b> SFI-48IDX5K-XXX		<b>REV</b> <b>6E</b>
DRAWN KM 2/8/2017 DRAWING SIZE B	CHECKED MS 5/30/2017 REV. DATE 1/30/2019	APPR. MS 5/30/2017 SHT 5 OF 5

# **Material Test Reports**



## STRAIGHT BILL OF LADING - Loading Copy - Not Negotiable

PLACE  
PRO-LABEL  
HERE

CPU

(Name of Carrier)

SHIPPER: <b>FORT WORTH F &amp; D HEAD COMPANY</b>				DATE: <b>5/16/2019</b>	SALES ORDER NUMBER: <b>621301</b>
STREET: <b>3040 PEDEN ROAD, FORT WORTH, TX</b>		ZIP CODE: <b>76179</b>		BILL TO:	
CONSIGNEE: <b>SYNERGY FABRICATIONS INC</b>		CONSIGNEE PHONE NO: <b>(817) 832-6735</b>		STREET ADDRESS:	
STREET: <b>1432 E DEVITT ST</b>	CITY: <b>FORT WORTH TX</b>	STATE: <b>TX</b>	ZIP CODE: <b>76119</b>	CITY:	STATE: ZIP:

No. Shipping Units	(X) HM	Kind of Packaging, Description of Articles, Special Marks and Exceptions			Weight (Subject to Correction)	Class or Rate
4		48 X 3.5	HOT PRESS HEMI	STL TANKEND UNF	16,604	50
1		ENVELOPE			2	
16						
5-17-19						
		(12) SM Energy 48" Hemis				
		SP1-4810 & SK - 097				
		QC APPROVAL				
		BY: D.M.				
		DATE: 5-21-2019				
		102				
Tt. # of Units	P.O. Number:	Customer No:			Total Wt.	
5	203612	4266 217592			16,606	50

NMFC Item 180690, Sub. 4/ Company check acceptable: ☐ Yes ☐ No

Remit: <b>FORT WORTH F &amp; D HEAD COMPANY</b>	<b>COD</b> Amt: \$	C.O.D. Fee:
C.O.D. TO: <b>P.O. BOX 79700</b>		Prepaid <input type="checkbox"/> \$
ADDRESS: <b>SAGINAW, TEXAS 76179</b>		Collect <input type="checkbox"/> \$
Note - Where the rate is dependent on value, shippers are required to state specifically in writing the agreed or declared value of the property. The agreed or declared value of the property is hereby specifically stated by the shipper to be not exceeding.	Subject to Section of the conditions, if this shipment is to be delivered to the consignee without recourse on the consignor, the consignor shall sign the following statement. The carrier shall not make delivery of this shipment without payment of freight and all other lawful charges.	Total Charges \$
\$ _____ per _____	(Signature of Consignor)	<b>FREIGHT CHARGES</b> Prepaid <input type="checkbox"/> Collect <input checked="" type="checkbox"/>
		FREIGHT COLLECT EXCEPT WHEN PREPAID BOX ABOVE IS CHECKED.

Received subject to the classification and tariffs in effect on the date of the issue of this Bill of Lading, the property described above in apparent good order, except as noted (contents and condition of contents of packages unknown), marked, consigned, and destined as indicated above which said carrier (the word carrier being understood throughout this contract as meaning any person or corporation in possession of the property under the contract) agrees to carry its usual place of delivery at said destination, if on its route, otherwise to deliver to another carrier on the route to said destination. It is mutually agreed as to each carrier of all or any of, said property over all any portion of said route to destination and as to each party at any time interested in all or any said property, that every service to be performed hereunder shall be to all the bill of lading terms and conditions in the governing classification on the date of shipment.

Shipper hereby certifies that he is familiar with all the bill of lading terms and conditions in the governing classification and the said terms and conditions are hereby agreed to by the shipper and accepted for himself and his assigns.

SHIPPER: <b>FORT WORTH F &amp; D HEAD CO</b>	CARRIER:
PER DATE <b>5/16/2019</b>	PER DATE
PERMANENT ADDRESS <b>3040 PEDEN ROAD, FORT WORTH, TX 76179, (817) 236-8773</b>	MARK "X" IN "HM" COLUMNS FOR HAZARDOUS MATERIALS



## 3rd

PLACE  
PRO-LABEL  
HERE

CPU

(Name of Carrier)

SHIPPER: <b>FORT WORTH F &amp; D HEAD COMPANY</b>				DATE: <b>5/17/2019</b>	SALES ORDER NUMBER: <b>621301</b>
STREET: <b>3040 PEDEN ROAD, FORT WORTH, TX</b>		ZIP CODE: <b>76179</b>		BILL TO:	
CONSIGNEE: <b>SYNERGY FABRICATIONS INC</b>		CONSIGNEE PHONE NO: <b>(817) 832-6735</b>		STREET ADDRESS:	
STREET: <b>1432 E DEVITT ST</b>	CITY: <b>FORT WORTH</b>	STATE: <b>TX</b>	ZIP CODE: <b>76119</b>	CITY:	STATE: ZIP:

No. Shipping Units	(X) HM	Kind of Packaging, Description of Articles, Special Marks and Exceptions			Weight (Subject to Correction)	Class or Rate
4		48 X 3.5	HOT PRESS HEMI	STL TANKEND UNF	16,604	50
76		ENVELOPE			2	
5-18-99						
		(12) SM Energy 48" Hemis				
		SP1 - 4810 x SK - 097				
		<b>QC APPROVAL</b>				
		BY: DM				
						102
		<b>DATE:</b> 5-21-2019				
Tt. # of Units	P.O. Number:	Customer No:			Total Wt.	
5	203612	4266			217592	16,606
						50

**NMFC Item 180690, Sub. 4/ Company check acceptable:** ☐ Yes ☐ No

<b>Remit:</b> FORT WORTH F & D HEAD COMPANY <b>C.O.D. TO:</b> P.O. BOX 79700 <b>ADDRESS:</b> SAGINAW, TEXAS 76179	<div style="font-size: 48pt; font-weight: bold; text-align: center;">COD</div> Amt: \$	<b>C.O.D Fee:</b> Prepaid <input type="checkbox"/> \$ Collect <input type="checkbox"/> \$
<p>Note - Where the rate is dependent on value, shippers are required to state specifically in writing the agreed or declared value of the property.</p> <p>The agreed or declared value of the property is hereby specifically stated by the shipper to be not exceeding.</p>	<p>Subject to Section of the conditions, if this shipment is to be delivered to the consignee without recourse on the consignor, the consignor shall sign the following statement.</p> <p>The carrier shall not make delivery of this shipment without payment of freight and all other lawful charges.</p>	<b>Total Charges \$</b> <div style="text-align: center; font-weight: bold;">FREIGHT CHARGES</div> Prepaid <input type="checkbox"/> Collect <input checked="" type="checkbox"/>
\$ _____ per _____	_____ (Signature of Consignor)	FREIGHT COLLECT EXCEPT WHEN PREPAID BOX ABOVE IS CHECKED

Received subject to the classification and tariffs in effect on the date of the issue of this Bill of Lading, the property described above in apparent good order, except as noted (contents and condition of contents of packages unknown), marked, consigned, and destined as indicated above which said carrier (the word carrier being understood throughout this contract as meaning any person or corporation in possession of the property under the contract) agrees to carry its usual place of delivery at said destination, if on its route, otherwise to deliver to another carrier on the route to said destination. It is mutually agreed as to each carrier of all or any of, said property over all any portion of said route to destination and as to each party at any time interested in all or any said property, that every service to be performed hereunder shall be to all the bill of lading terms and conditions in the governing classification on the date of shipment.

Shipper hereby certifies that he is familiar with all the bill of lading terms and conditions in the governing classification and the said terms and conditions are hereby agreed to by the shipper and accepted for himself and his assigns.

SHIPPER: FORT WORTH F & D HEAD CO		CARRIER:	
PER	DATE 5/17/2019	PER	DATE
PERMANENT ADDRESS OF SHIPPER:	3040 PEDEN ROAD, FORT WORTH, TX 76179, (817) 236-8773	MARK "X" IN "HM" COLUMNS FOR HAZARDOUS MATERIALS	

PLACE  
PRO-LABEL  
HERE

(Name of Carrier)

SHIPPER: FORT WORTH F & D HEAD CO		CARRIER:
PER	DATE 5/17/2019	PER DATE
PERMANENT ADDRESS OF SHIPPER:	3040 PEDEN ROAD, FORT WORTH, TX 76179, (817) 236-8773	MARK "X" IN "HM" COLUMNS FOR HAZARDOUS MATERIALS

# COVER SHEET

CUSTOMER SYNERGY FABRICATION		CUSTOMERS P.O. NUMBER 203612			DATE 5/13/19	
CODE LETTER	QTY.	SIZE-OD. OR ID.	THICKNESS	PLATE MFG.	HEAT NUMBER	SLAB NUMBER
CODB ✓	4 ✓	48"ID ✓	3 1/2"NOM ✓	JSW STEEL	S27086	04B1
COEJ ✓	4 ✓	48"ID ✓	3 1/2"NOM ✓	JSW STEEL	S26396	08B1
COEK ✓	4 ✓	48"ID ✓	3 1/2"NOM ✓	JSW STEEL	S26397	09B1

HOT FORMED ☒

MATERIAL SA516-70 NORM ✓  
CHARPY @ -30 ✓

## STYLE HEMI

SF:  
BEVEL: 22 DEG ✓  
DR:  
MIN: 3.1" ✓

OUTSIDE ☒INSIDE 

LAND

ICR

WO# 217592

FORT WORTH F & D HEAD COMPANY CERTIFIES THAT HEADS MANUFACTURED FROM MATERIAL LISTED ON THIS REPORT COMPLY WITH ASME CODE SECTION II & SECTION VIII, DIVISION I. ALL HEADS COMPLY WITH UG-81(a) AND UCS 79.

WE CERTIFY THAT THESE HEADS WERE HOT FORMED ABOVE 1,650 DEGREES FAHRENHEIT, HELD FOR A MINIMUM OF 10 MINUTES, AND AIR COOLED.

135

*Roxanne L. Taylor*  
FORT WORTH F & D HEAD CO.



10817 Sanden Dr. Dallas, Texas 75238

Phone: 972-276-0846

Web: www.bondedndt.com

Customer: Fort Worth F&D Head, Co. Inc.

Report Number: KP-MPTR-05-10-2019-17-46-03

PO Number:

Sales Order Number: 6736

Report Date & Time: 05/10/2019 12:43 PM

## Magnetic Particle Test Report

Material: 516-70 CARBON STEEL	Thickness: 3.50"
Acceptance Criteria: ASME Sec. VIII Div. 1 Appendix 6	BI Proc Rev: BI MT 1.0 Rev. 13
Equipment: Yoke	AC or DC: AC
Model: Contour Probe B-100 (yoke)	Cal Date Due: 05/10/2019
Wet or Dry Particles: Dry	Visible Media: 2 Yellow
Fluorescent Media N/A	Cir Amps:
Long Amps:	Light Equipment: Flashlight
Black Light / 1000 uW/CM2 Min. @ Exam Surface: N/A	White Light / 100 fc Min. @ Exam Surface: OK
DC Lift Test 40lb. - Weight SN:	AC Lift Test 10lb. - Weight SN: 1023

ID Number	Description	Acc	Rej	Flaw Description Location
W/O: 217592; Heat Code: CODB	Qty: 4 Heads	✓		N/A
W/O: 217592; Heat Code: GOEJ	Qty: 4 Heads	✓		N/A
W/O: 217592; Heat Code: GOEK	Qty: 4 Heads	✓		N/A

### Notes

Dry magnetic particle inspection performed on 100% of bevels after forming to locate possible defects. No relevant indications noted upon completion of this inspection.

Inspected By: [Signature]	Reviewed By: [Signature]	Approved By: [Signature]	Flaw Description Location
---------------------------	--------------------------	--------------------------	---------------------------



10817 Sanden Dr. Dallas, Texas 75238

Phone: 972-276-0846

Web: www.bondedndt.com

Customer: Fort Worth F&D Head, Co. Inc.

Report Number: CS-UR-05-10-2019-17-51-12

PO Number:

Sales Order Number: 6791

Report Date & Time: 05/10/2019 12:47 PM

## Ultrasonic Report

BI Proc Rev: UT 1.0 REV 17	Acceptance Criteria: ASTM-A578
Material: SA516 GR70	Material Thickness: 3.5"
Couplant: Water	

### Ultrasonic Instrument Identification

Manufacturer: G.E.	Model: USM 36
Display Type: A-scan	Serial Number: 15037593
Cal Due: 7/3/19	Software Ver: USM_36(4.2.0.17, 3/April/2014)

### Search Unit Identification

Manufacturer	SN	Frequency	Size	Shape	Angle	Cable Type	Cable Length
Panametrics	23152	2.25 Mhz	1"	Round	0°	B.N.C. to B.N.C.	6'

### Calibration Information

Setup No	Range Used	Dampening	Reject	Velocity	Delay	Calibration Block ID	Reflector Size	Reference Level Gain
1	10"	1000	off	.2331	.683	IIW TYPE II	Part Back Wall Reflection	37DB

### Testing Disposition

Part ID	Weld Identification	Scan Surface/Condition	Acc	Rej	Indication % of DAC	Indication Length x Depth	Indication (x,y)
W/O-217592, SA516 GR70, 48" ID x 3.5"	CODB (Qty-4)	Moderate Grain	✓				
	COEJ (Qty-4)	Moderate Grain	✓				
	COEK (Qty-4)	Moderate Grain	✓				

### Notes

(After Forming)Level B

Level B (Qty-4) Section	58	Level B	
-------------------------	----	---------	--





JSW Steel (USA) INC.  
5200, East McKinney Road,  
BAYTOWN, TX 77523

# METALLURGICAL TEST REPORT

P.36576

MET - 04 Rev. No.: 3 Rev. Date: 02/27/2018

4/11/2019

Bulletin	Order Item	Heat	PO No.	Shipping Mode	Order Dimensions	Slab Origin	TC No.
T053335	JSW12205-01	S27086	V16849	TRUCK	3.5x73x292	BRAZIL	T053335-7086-1
TEST FREQUENCY TO MEET ASTM A370 AND A573NACE MR0175							
Plates Certified for the Following grades ASTM-A516-70, ASME-SA516-70 2017 EDITION TN				Specifications TEST NORMALIZED AT 1650 °F FOR 105 MINS		Marking Instructions Stencil in 2 location(s); X Loc. 18 Y Loc. 30; CUST; MADE IN USA PN PO; DIM GRADE; FREIGHT ORDER ITEM PLATE ID SHIPWEEK SLAB ID TRANSMODE Stamp in 2 location(s); X Loc. 18 Y Loc. 12; Slab ID; Slab ID	
Hot Rolled Carbon Steel Plates Plates Manufactured In the USA							
Sold To: LEECO STEEL LLC. 1011 WARRENVILLE RD LISLE, IL 60532							
Ship To: Fort Worth FD Head Company 3040 E. Peden Rd. Fort Worth, TX 76179							

Test	C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	Al	N	V	B	Ti	Nb	Ca	CE
LADLE	0.24	1.16	0.012	0.004	0.19	0.020	0.010	0.010	0.000	0.000	0.032	0.0070	0.004	0.0000	0.002	0.001	0.0024	0.44

Carbon Equivalent CE = C + Mn/6 + (Cr + Mo + V)/5 + (Ni + Cu)/15  
PCM = C + Si/30 + Mn/20 + Cu/20 + Ni/60 + Cr/20 + Mo/15 + V/10 + Sb

Plate	Slab Identity	Gauge Tested	Test Cond	Test Dir.	Yield Point	Tensile Stgth.	Elong in 2"	YS/UTS Ratio	Yield Strength Determined At	Temp	Test1	Test2	Test3	Avg	Test1	Test2	Test3	Avg
1123493A	04B1	3.5000	TN	T	53	81	31.0%	0.65	0.2%	-30	66	68	60	65				

HARDNESS				
Plate	Test Method	Test1	Test2	Avg
1123493	ROCKWELL C	2	2	2

## Plates Certified For The Above Tests

Material	Thick(IN)	Width(IN)	Len(IN)	Wgt(LB)	Material	Thick(IN)	Width(IN)	Len(IN)	Wgt(LB)	Material	Thick(IN)	Width(IN)	Len(IN)	Wgt(LB)
1123493A	3.5000	73.000	292.00	21158.262										

DIN: EN 10204 2004 3.1 This is to certify that the product described herein was manufactured, sampled, and tested in accordance with the specifications and requirements in such specifications. Fine Grain, Si-Al Fully Killed Steel. We certify that delivery of this product with the requirement of the specification and purchase order received from customer. DRC Conflict Free. Does not contain Hg.

P.O. 47610

O.C. By  
J.D.

April W

April Watkins 8323835325 april.watkins@jswsteel.us

Page 1 of 1





JSW Steel (USA) INC.  
5200 East McKinney Road,  
BAYTOWN, TX 77523

# METALLURGICAL TEST REPORT

MET - 04 Rev. No.: 3 Rev. Date: 02/27/2018

4/17/2019

Bulletin	Order Item	Heat	PO No.	Shipping Mode	Order Dimensions	Slab Origin	TC No.
T053818	JSW12205-01	S26396	V16849	TRUCK	3.5x73x292	BRAZIL	T053818-6396-1

TEST FREQUENCY TO MEET ASTM A370 AND A673 NACE MR0175

COEJ

Plates Certified for the Following grades  
ASTM-A516-70, ASME-SA516-70 2017 EDITION TN

Specifications  
TEST NORMALIZED AT 1650 °F FOR 105 MINS

Marking Instructions  
Stencil in 2 location(s); X Loc. 18 Y Loc. 30; CUST; MADE IN USA PN PO;  
DIM GRADE; FREIGHT ORDER ITEM PLATE ID SHIPWEEK SLAB ID  
TRANSMODE Stamp in 2 location(s); X Loc. 18 Y Loc. 12; Slab ID; Slab ID

Hot Rolled Carbon Steel Plates  
Plates Manufactured In the USA

Sold To: LEECO STEEL LLC. 1011 WARRENVILLE RD LISLE, IL 60532

Ship To: Fort Worth FD Head Company 3040 E. Peden Rd. Fort Worth, TX 76179

Test	C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	Al	N	V	B	Ti	Nb	Ca	CE
LADLE	0.24	1.14	0.012	0.004	0.18	0.020	0.010	0.020	0.000	0.000	0.034	0.0050	0.004	0.0001	0.002	0.001	0.0024	0.44

Carbon Equivalent CE = C + Mn/6 + (Cr + Mo + V)/5 + (Ni + Cu)/15

PCM = C + Si/30 + Mn/20 + Cu/20 + Ni/60 + Cr/20 + Mo/15 + V/10 + 5B

COEJ

Plate	Slab Identity
1123488A	08B1

Gauge Tested	Test Cond	Test Dir.	Yield Point	Tensile Stgth.	Elong in 2"	YS/UTS Ratio	Yield Strenght Determined At
3.5000	TN	T	52	78	28.0%	0.67	0.2%

Impact Test (LCVN) Full Energy in F/ft <sup>2</sup> °F							
Temp	Test1	Test2	Test3	Avg	Test1	Test2	Test3
-30	88	95	82	88			

HARDNESS					
Plate	Test Method	Test1	Test2	Test3	Avg
1123488	ROCKWELL C	2	4	6	4

Plates Certified For The Above Tests

Material	Thick(IN)	Width(IN)	Len(IN)	Wgt(LB)	Material	Thick(IN)	Width(IN)	Len(IN)	Wgt(LB)	Material	Thick(IN)	Width(IN)	Len(IN)	Wgt(LB)
1123488A	3.5000	73.000	292.00	21158.252										

DIN: EN 10204 2004 3.1 This is to certify that the product described herein was manufactured, sampled, and tested in accordance with the specifications and requirements in such specifications. Fine Grain, Si-Al Fully Killed Steel. We certify that delivery of this product with the requirement of the specification and purchase order received from customer. DRC Conflict Free. Does not contain Hg.



April Watkins 8323835325 april.watkins@jswsteel.us

Page 1 of 1

P.O. 47010

O.C. BY  
J.D.

April W



JSW Steel (USA) INC.  
5200, East McKinney Road,  
BAYTOWN, TX 77523

# METALLURGICAL TEST REPORT

MET-04 Rev. No. 3 Rev. Date: 02/27/2018

4/11/2019

Bulletin	Order Item	Heat	PO No.	Shipping Mode	Order Dimensions	Slab Origin	TC No.
T053336	JSW12205-01	S26397	V16849	TRUCK	3.5x73x292	BRAZIL	T053336-6397-1
TEST FREQUENCY TO MEET ASTM A370 AND A673 NACE MR0175							
COEK							
Plates Certified for the Following grades ASTM-A516-70, ASME-SA516-70 2017 EDITION TN				Specifications TEST NORMALIZED AT 1650 °F FOR 105 MINS		Marking Instructions Stencil in 2 location(s); X Loc. 18 Y Loc. 30; CUST; MADE IN USA PN PO; DIM GRADE; FREIGHT ORDER ITEM PLATE ID SHIPWEEK SLAB ID TRANS MODE Stamp in 2 location(s); X Loc. 18 Y Loc. 12; Slab ID; Slab ID; Slab ID	
Hot Rolled Carbon Steel Plates Plates Manufactured In the USA							
Sold To: LEECO STEEL LLC, 1011 WARRENVILLE RD LISLE, IL 60532							
Ship To: Fort Worth FD Head Company 3040 E. Peden Rd. Fort Worth, TX 76179							

Test	C	Mn	P	S	Si	Cu	Ni	Cr	Mo	Sn	Al	N	V	B	Ti	Nb	Ca	CE
LADLE	0.23	1.16	0.013	0.004	0.18	0.030	0.010	0.020	0.000	0.000	0.035	0.0060	0.004	0.0001	0.002	0.002	0.0016	0.43

Carbon Equivalent CE = C + Mn/6 + (Cr + Mo + V)/5 + (Ni + Cu)/15

PCM = C + Si/30 + Mn/20 + Cu/20 + Ni/60 + Cr/20 + Mo/15 + V/10 + 58

Plate	Slab Identity
1123489A	09B1

Gauge Tested	Test Cond	Test Dir.	Yield Poi. rt	Tensile Stgth.	Elong in 2"	YS/UTS Ratio	Yield Strenght Determined At
3.5000	TN	T	52	77	29.0%	0.68	0.2%

Impact Test (LCVN) Full Energy in Ft/Lb °F								
Temp	Test1	Test2	Test3	Avg	Test1	Test2	Test3	Avg
-30	68	92	88	83				

HARDNESS					
Plate	Test Method	Test1	Test2	Test3	Avg
1123489	ROCKWELL C	2	2	2	2

## Plates Certified For The Above Tests

Material	Thick(IN)	Width(IN)	Len(IN)	Wgt(LB)	Material	Thick(IN)	Width(IN)	Len(IN)	Wgt(LB)	Material	Thick(IN)	Width(IN)	Len(IN)	Wgt(LB)
1123489A	3.5000	73.000	292.00	21158.262										

DIN: EN 10204 2004 3.1 This is to certify that the product described herein was manufactured, sampled, and tested in accordance with the specifications and requirements in such specifications. Fine Grain, Si-Al Fully Killed Steel. We certify that delivery of this product with the requirement of the specification and purchase order received from customer. DRC Conflict Free. Does not contain Hg.

Po. 47010

O.C. 39  
J.D.

April W

April Watkins 8323835325 april.watkins@jswsteel.us

Page 1 of 1





# **Welders Log**

Welder	Stamp	Process	Orig Qual Date	2019											
				Jan	Feb	Mar	Apr	May	June	July	Aug	Sept	Oct	Nov	Dec
Manuel Castaneda	M	GMAW	2/18/2015	Inactive											
Julian Enriquez	JJ	GMAW	2/25/2015	1/8/2019				Inactive							
Julian Enriquez	JJ	GMAW-P	3/2/2015	1/2/2019				Inactive							
Julian Enriquez	JJ	FCAW	5/13/2015	1/8/2019				Inactive							
Jonathan Ortiz	JO	GMAW	2/27/2015	1/9/2019					6/3/2019						
Jonathan Ortiz	JO	FCAW	4/17/2015	1/9/2019					6/4/2019						
Jose Orosco	1	FCAW	5/25/2015	1/4/2019					6/3/2019						
Jose Orosco	1	GMAW	2/25/2015	1/2/2019					6/6/2019						
Guadalupe Villagomez	4	GMAW	8/15/2017	1/7/2019					6/3/2019						
Salvador Garcia	S	FCAW	3/3/2017	Inactive											
Salvador Garcia	S	GMAW	3/9/2017	Inactive											
Manuel Castaneda Sr.	2	GMAW	2/19/2015	1/3/2019					6/3/2019						
Manuel Castaneda Sr.	2	FCAW	5/25/2015	1/9/2019					6/5/2019						
Jose Nunez	N	SAW	10/22/2015	1/24/2019					6/3/2019						
Jose Nunez	N	GMAW	8/7/2015	1/8/2019					6/4/2019						
Jose Nunez	N	FCAW	8/9/2015	1/22/2019					6/4/2019						
Adrian Rodriguez	R	FCAW	8/15/2016	1/11/2019					6/6/2019						
Adrian Rodriguez	R	GMAW	8/15/2016	1/2/2019					6/7/2019						
Adrian Rodriguez	R	SAW	8/17/2016	1/24/2019					6/5/2019						
Jose Licerio	L	GMAW	1/27/2017	1/8/2019					6/3/2019						
Jose Licerio	L	SAW	3/2/2017	1/18/2019					6/17/2019						
Jose Licerio	L	FCAW	7/27/2017	1/7/2019					6/3/2019						
Gregory Scott	AA	GMAW	3/2/2018	1/2/2019					6/3/2019						
Gregory Scott	AA	SAW	5/16/2018	1/18/2019					6/17/2019						
Marcos Alvarez	Z	GMAW	3/9/2017	Inactive											
Marcos Alvarez	Z	FCAW	3/9/2017	Inactive											
Cesar Herrera	I	GMAW	5/23/2017	1/7/2019		Inactive									
Jose G. Lopez	G	GMAW	4/20/2017	1/10/2019					6/3/2019						
Jose G. Lopez	G	FCAW	4/20/2017	1/22/2019					6/3/2019						
Jose G. Lopez	G	SAW	12/4/2017	1/29/2019					6/11/2019						
Sergio Cervantez	D	GMAW	9/12/2018	Inactive											

[illegible]


# **HYDRO CHART**

## SFI Hydrostatic Test Report

Job Description: *SFI-48IDX5K-101 & 102*

Gauge Information	
Serial Number	780817
Model	15KPSIXP2I
Message Store	SYNERGY 15K
Units	PSI

Run Info	
Start Time	8/9/19 8:15:35 AM
Stop Time	8/9/19 1:53:23 PM
Logging Interval	10



# **HEAT TREAT REPORTS**

## Synergy Fabrication, Inc. PWHT PROCEDURE

### PWHT Furnace Specifications

Serial SFI-48IDX5K-101, 102

PO#203882

Part(s) (2) - 48" x 5K Spheres

1. Two thermocouples are required on every single part up to 15 feet long. An additional thermocouple is required for every additional 15 feet or fraction thereof. No two couples may be more than 15 feet apart. Placement of thermocouples must represent the maximum temperature spread expected both vertically and horizontally. Measurement of furnace gas temperature alone is not acceptable.
2. When more than one part is heat treated in one furnace charge, thermocouples shall be placed on parts at bottom center, and top of the charge or in other zones of possible temperature variation so that the temperature indicated shall be true temperature for all parts in those zones.
3. The temperature of the furnace shall not exceed 800°F at the time the part(s) is placed in it.
4. Above 800°F, the rate of heating shall not be more than 100°F per hour. During the heating period there shall be no greater variation in temperatures throughout the charge than 250 F.
5. Minimum hold at 1150°F for 2 hour(s) 30 minutes. During the holding period there shall not be a variation of more than 150 F between the highest and lowest temperatures recorded.
6. During the heating and holding periods, the furnace atmosphere shall be so controlled as to avoid excessive oxidation of the surface of the part(s) being heat treated. The furnace shall be of such design as to prevent direct impingement of the flame on the part(s).
7. Above 800 F, cooling shall be done in a closed furnace at a rate not to exceed 125°F per hour. From 800 F the part(s) may be cooled in still air.
8. Tack welds made to the part(s) for the thermocouple placement shall be made using a welding procedure qualified in accordance with Section IX of the ASME Code.
9. Holding temperature may not exceed 1200°F nor may time at temperature exceed 2 hour(s) 45 minutes.

Heating rate 100°F/Hr MAX

Cooling rate 125°F/Hr MAX

10. Additional Instructions or Requirements



Southwest Metal Treating Corp.

## CERTIFICATION

Synergy Fabrication, INC.  
1432 Devitt  
Fort Worth, TEXAS 76119 USA

Certification ID: **114283-1**  
Date: 8/8/2019  
Cert Date: 08/08/2019  
Purchase Order: 203882  
Material: All

Page 1 of 1

We are pleased to provide you with the following Certification.

Part Number	Part Description	Qty	Weight
48" ID SPHERICAL SAND SEPERATOR	48" 5K SPHERE, S/N: SFI-48IDx5K-102	1	10,410.00

Customer Requirements						
Inspection Type	U Of M	Lower Spec	Lower Control	Target Value	Upper Control	Upper Spec

Results							
Inspection Type	Qty Tested	Qty Passed	Qty Rejected	Scale	Minimum	Maximum	Range
	0	0	0				

### Miscellaneous Comments

#### PWHT Process:

#### Post Weld Heat Treat

Step 1. Start Furnace at 800°F

Step 2. Heat 100°F /hr Max to 1150°F ±50°F


Step 3. Hold at 1150°F ±50°F for 2 Hrs 30 Min

Step 4. Cool 125°F /hr Max to 800°F

Step 5. Pull Parts

### Certification Statement

SWMT is please to provide you with the following certification.

  
Certified By: James Arnold  
Title: Plant Manager  
Date: 08/08/2019



James  
Arnold

Digitally signed by James  
Arnold  
DN: cn=James Arnold,  
o=SOUTHWEST METAL  
TREATING, ou,  
email=JAMESA@SWMT.NET,  
c=US  
Date: 2019.08.12 09:42:57  
-05'00'


Ref Time  
8/7/2019  
4:35 PM

## Furnace C-1

8/7/2019 11:13:29 AM

2:30

8/7/2019 11:13:29 PM



TC 3 TC 4

# **NDE REPORTS**



10817 Sanden Dr. Dallas, Texas 75238

Phone: 972-276-0846

Web: www.bondedndt.com

Customer: Synergy Fabrication, Inc.

Report Number: GB-RER-08-04-2019-23-46-46-REV1

PO Number: SFI-48IDx5K-102

Sales Order Number: 8052

Report Date & Time: 08/ 4/2019 06:39 PM

## Radiographic Examination Report

BI Proc Rev: BI RT 1.0 REV 19	Acceptance Criteria: ASME Sec. VIII Div. 1 UW 51
Percent or Random: 100%	Xray KV: N/A
Xray MA: N/A	Xray Focal Spot Size: N/A
Isotope: Co 60	Isotope Physical Size: .122
Number of Exposures: 2	Number of Film Per Holder: 1
Base Material Type: CS	Diameter: 48ID
Thickness: 3.500	Weld Thickness: 3.625
Weld Reinforcement Thickness: .125	IQI Type: (Film Side) ASTM C-Set
IQI Designated Hole or Wire: #13 wire	Shim: N/A
Exposure Time: 9min - 14min	Film Size: 7" x 17"
MFR + Film Speed: Agfa D7	Min Source to Object Distance: 24
Source Side Object to Film Distance: 3.500	Wall Exposure: Single
Wall View: Single	Chemistry: Manual


Serial Number	Weld Number	Film	Acc	Rej	Def Codes	Film Density	Remarks
SFI-48IDx5K-102	Cirth	1-2		✗	SL		
		2-3		✗	SL, P		
		3-4	✓				
		4-5	✓				
		5-6	✓				
		6-7	✓				
		7-8	✓				
		8-9	✓		SL		Less than .750
		9-10	✓				
		10-11	✓				
		11-12	✓				
		12-13	✓		P		Pass on cap
		13-14	✓		P		Pass on cap
		14-1	✓				

### Notes

11qty. 7x17(D7)

3qty. 7x17(D5)

3 of 3

Radiographer: Leon Baker			
Level II: Gerimaine Bradford		Level III:	

cr = crack	ip = incomplete penetration	iu = internal undercut	if = incomplete fusion	eu = external undercut	bt = burn through
lc = low crown	si = slag inclusion	sb = suck back (concave root)	sl = slag line	wt = wagon tracks	p = porosity



10817 Sanden Dr. Dallas, Texas 75238

Phone: 972-276-0846

Web: www.bondedndt.com

Customer: Synergy Fabrication, Inc.

Report Number: GB-RER-08-06-2019-19-08-42

PO Number: SFI-48IDx5K-102

Sales Order Number: 8082

Report Date & Time: 08/ 6/2019 02:02 PM

## Radiographic Examination Report

BI Proc Rev: BI RT 1.0 REV 19	Acceptance Criteria: ASME Sec. VIII Div. 1 UW 51
Percent or Random: 100%	Xray KV: N/A
Xray MA: N/A	Xray Focal Spot Size: N/A
Isotope: Ir 192	Isotope Physical Size: .138
Number of Exposures: 1	Number of Film Per Holder: 1
Base Material Type: CS	Diameter: 48ID
Thickness: 3.500	Weld Thickness: 3.625
Weld Reinforcement Thickness: .125	IQI Type: (Film Side) ASTM C-Set
IQI Designated Hole or Wire: #13 wire	Shim: N/A
Exposure Time: 1hr 30min	Film Size: 7" x 17"
MFR + Film Speed: Agfa D7	Min Source to Object Distance: 27.5
Source Side Object to Film Distance: 3.625	Wall Exposure: Single
Wall View: Single	Chemistry: Manual

Serial Number	Weld Number	Film	Acc	Rej	Def Codes	Film Density	Remarks
SFI-48IDx5K-102	Girth	1-2	✓				
SFI-48IDx5K-102	Girth	2-3	✓				

### Notes

2qty. 7x17(D5)

1 of 6

Radiographer: Andy Hathaway			
Level II: Gerimaine Bradford		Level III:	

cr = crack	ip = incomplete penetration	lu = internal undercut	if = incomplete fusion	eu = external undercut	bt = burn through
lc = low crown	si = slag inclusion	sb = suck back (concave root)	sl = slag line	wt = wagon tracks	p = porosity

# **PSV CERTIFICATION**